

CONTENTS

1	Scope	9
2	Normative references	9
3	Terms and definitions	9
4	Abbreviated terms	10
5	Conditions for attribute inclusion	10
6	Common data attribute types	11
6.1	General	11
6.2	Quality	11
6.2.1	Overview	11
6.2.2	Validity	12
6.2.3	Detail quality	12
6.2.4	Source	13
6.2.5	Test	14
6.2.6	Blocked by operator	14
6.2.7	Quality in the client server context	14
6.2.8	Relation between quality identifiers	15
6.3	Analogue value	17
6.4	Configuration of analogue value	17
6.5	Range configuration	18
6.6	Step position with transient indication	18
6.7	Pulse configuration	19
6.8	Originator	19
6.9	Unit definition	20
6.10	Vector definition	20
6.11	Point definition	21
6.12	CtlModels definition	21
6.13	SboClasses definition	21
7	Common data class specifications	21
7.1	General	21
7.2	Name spaces	21
7.3	Common data class specifications for status information	22
7.3.1	Application of services	22
7.3.2	Single point status (SPS)	22
7.3.3	Double point status (DPS)	23
7.3.4	Integer status (INS)	24
7.3.5	Protection activation information (ACT)	25
7.3.6	Directional protection activation information (ACD)	26
7.3.7	Security violation counting (SEC)	26
7.3.8	Binary counter reading (BCR)	27
7.3.9	Histogram (HST)	28
7.4	Common data class specifications for measurand information	29
7.4.1	Application of services	29
7.4.2	Measured value (MV)	30
7.4.3	Complex measured value (CMV)	31
7.4.4	Sampled value (SAV)	32

7.4.5	Phase to ground related measured values of a three phase system (WYE).....	33
7.4.6	Phase to phase related measured values of a three phase system (DEL).....	34
7.4.7	Sequence (SEQ).....	35
7.4.8	Harmonic Value (HMV).....	36
7.4.9	Harmonic value for WYE (HWYE).....	37
7.4.10	Harmonic value for DEL (HDEL).....	38
7.5	Common data class specifications for controls.....	39
7.5.1	Application of services.....	39
7.5.2	Controllable single point (SPC).....	40
7.5.3	Controllable double point (DPC).....	41
7.5.4	Controllable integer status (INC).....	42
7.5.5	Binary controlled step position information (BSC).....	43
7.5.6	Integer controlled step position information (ISC).....	44
7.5.7	Controllable analogue process value (APC).....	45
7.6	Common data class specifications for status settings.....	46
7.6.1	Application of services.....	46
7.6.2	Single point setting (SPG).....	46
7.6.3	Integer status setting (ING).....	47
7.6.4	Object reference setting group (ORG).....	47
7.6.5	Time setting group (TSG).....	48
7.7	Common data class specifications for analogue settings.....	49
7.7.1	Application of services.....	49
7.7.2	Analogue setting (ASG).....	50
7.7.3	Setting curve (CURVE).....	51
7.7.4	Curve shape setting (CSG).....	52
7.8	Common data class specifications for description information.....	53
7.8.1	Application of services.....	53
7.8.2	Device name plate (DPL).....	54
7.8.3	Logical node name plate (LPL).....	55
7.8.4	Curve shape description (CSD).....	55
8	Data attribute semantic.....	56
	Annex A (normative) Value range for units and multiplier.....	68
	Annex B (informative) Functional constraints.....	71
	Annex C (informative) Tracking of configuration revisions.....	2
	Figure 1 – Quality identifiers in a single client – server relationship.....	14
	Figure 2 – Quality identifiers in a multiple client – server relationship.....	15
	Figure 3 – Interaction of substitution and validity.....	16
	Figure 4 – Configuration of command output pulse.....	19
	Table 1 – Quality.....	11
	Table 2 – Analogue value.....	17
	Table 3 – Configuration of analogue value.....	17
	Table 4 – Range configuration.....	18
	Table 5 – Step position with transient indication.....	18

Table 6 – Pulse configuration	19
Table 7 – Originator	19
Table 8 – Values for orCat	20
Table 9 – Unit	20
Table 10 – Vector	20
Table 11 – Point	21
Table 12 – Name space attributes	22
Table 13 – Basic status information template.....	22
Table 14 – Single point status common data class definition	23
Table 15 – Double point status common data class specification.....	23
Table 16 – Integer status common data class specification	24
Table 17 – Protection activation information common data class specification	25
Table 18 – Directional protection activation information common data class specification	26
Table 19 – Security violation counting common data class specification	26
Table 20 – Binary counter reading common data class specification.....	27
Table 20.1 – Histogram common data class specification.....	28
Table 21 – Basic measurand information template	29
Table 22 – Measured value	30
Table 23 – Complex measured value.....	31
Table 24 – Sampled value.....	32
Table 25 – WYE.....	33
Table 26 – Delta	34
Table 27 – Sequence	35
Table 28 – Harmonic value	36
Table 29 – Harmonic values for WYE	37
Table 30 – Harmonic values for delta	38
Table 31 – Basic controllable status information template	39
Table 32 – Controllable single point	40
Table 33 – Controllable double point	41
Table 34 – Controllable integer status	42
Table 35 – Binary controlled step position information	43
Table 36 – Integer controlled step position information	44
Table 38– Controllable analogue process value.....	45
Table 39 – Basic status setting template	46
Table 40 – Single point setting.....	46
Table 41 – Integer status setting	47
Table 41.1 – Object reference setting group common data class specification	47
Table 41.2 – Time setting group common data class specification.....	48
Table 42 – Basic analogue setting template.....	49
Table 43 – Analogue setting.....	50
Table 44 – Setting curve	51
Table 44.1 – Curve shape setting.....	52

Table 45 – Basic description information template	53
Table 46 – Device name plate common data class specification	54
Table 47 – Logical node name plate common data class specification	55
Table 48 – Curve shape description common data class specification	55
Table 49 – Semantics of data attributes and data	56
Table A.1 – SI units: base units	68
Table A.2 – SI units: derived units	68
Table A.3 – SI units: extended units	69
Table A.4 – SI units: industry specific units	69
Table A.5 – Multiplier	70
Table B.1 – Functional constraints	71

INTERNATIONAL ELECTROTECHNICAL COMMISSION

COMMUNICATION NETWORKS AND SYSTEMS FOR UTILITY AUTOMATION

Deleted: IN SUBSTATIONS

Part 7-3: Basic communication structure – Common data classes

Deleted: for substation and feeder equipment

FOREWORD

- 1) The IEC (International Electrotechnical Commission) is a worldwide organisation for standardisation comprising all national electrotechnical committees (IEC National Committees). The object of the IEC is to promote international co-operation on all questions concerning standardisation in the electrical and electronic fields. To this end and in addition to other activities, the IEC publishes International Standards. Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organisations liaising with the IEC also participate in this preparation. The IEC collaborates closely with the International Organisation for Standardisation (ISO) in accordance with conditions determined by agreement between the two organisations.
- 2) The formal decisions or agreements of the IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested National Committees.
- 3) The documents produced have the form of recommendations for international use and are published in the form of standards, technical specifications, technical reports or guides and they are accepted by the National Committees in that sense.
- 4) In order to promote international unification, IEC National Committees undertake to apply IEC International Standards transparently to the maximum extent possible in their national and regional standards. Any divergence between the IEC Standard and the corresponding national or regional standard shall be clearly indicated in the latter.
- 5) The IEC provides no marking procedure to indicate its approval and cannot be rendered responsible for any equipment declared to be in conformity with one of its standards.
- 6) Attention is drawn to the possibility that some of the elements of this International Standard may be the subject of patent rights. The IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 61850-7-3 has been prepared by IEC technical committee 57: Power system control and associated communications.

This CD of Edition 2 is based on the following documents:

↓S	Report on voting
<u>61850-7-3:2003</u>	▼
<u>CD</u>	
<u>57/779/CD</u>	<u>57/843/CC</u>

Deleted: The text of this standard

Deleted: FD

Deleted: 57/618/FDIS

Deleted: 57/635/RVD

Deleted: Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

IEC 61850 consists of the following parts, under the general title *Communication networks and systems in substations*.

Part 1: Introduction and overview

Part 2: Glossary

Deleted: 1

Part 3: General requirements

Part 4: System and project management

Part 5: Communication requirements for functions and device models

Deleted: 2

Part 6: Configuration description language for communication in electrical substations related to IEDs

Deleted: 1

Part 7-1: Basic communication structure for substation and feeder equipment – Principles and models

Part 7-2: Basic communication structure for substation and feeder equipment – Abstract communication service interface (ACSI)

Part 7-3: Basic communication structure for substation and feeder equipment – Common data classes

Part 7-4: Basic communication structure for substation and feeder equipment – Compatible logical node classes and data classes

Part 8-1: Specific communication service mapping (SCSM) – Mappings to MMS (ISO/IEC 9506-1 and ISO/IEC 9506-2) and to ISO/IEC 8802-3

Deleted: 1

Part 9-1: Specific communication service mapping (SCSM) – Sampled values over serial unidirectional multidrop point to point link

Part 9-2: Specific communication service mapping (SCSM) – Sampled values over ISO/IEC 8802-3

Deleted: 1

Part 10: Conformance testing

Deleted: 1

The content of this part of IEC 61850 is based on existing or emerging standards and applications. In particular the definitions are based upon:

- the specific data types defined in IEC 60870-5-101 and IEC 60870-5-103;
- the common class definitions from the *Utility Communication Architecture 2.0: Generic Object Models for Substation & Feeder Equipment (GOMSFE) (IEEE TR 1550)*.

TC57, WG10 is currently preparing the second edition of IEC 61850. During the recent WG meeting, it was decided to circulate in a first step the following parts as CD: Part 6, 7-2, 7-3, 7-4, 8-1 and 9-2. The purpose of these CDs is, to give the national committees a first possibility to comment on the principle direction of Edition 2. There may still be some missing elements in these CDs.

It is intended, to circulate by the end of 2007 a CDV of Edition 2. For that CDV, other parts, in particular part 1, 5 and 7-1 will be prepared as well.

Deleted: The committee has decided that the contents of this publication will remain unchanged until 2005. At this date, the publication will be ¶

- reconfirmed;¶
- withdrawn;¶
- replaced by a revised edition, or¶
- amended.¶

A bilingual version of this standard may be issued at a later date.¶

INTRODUCTION

This document is part of a set of specifications, which details layered substation communication architecture. This architecture has been chosen to provide abstract definitions of classes and services such that the specifications are independent of specific protocol stacks and objects. The mapping of these abstract classes and services to communication stacks is outside the scope of IEC 61850-7-x and may be found in IEC 61850-8-x (station bus) and IEC 61850-9-x (process bus).

IEC 61850-7-1 gives an overview of this communication architecture. This part of IEC 61850 defines common attribute types and common data classes related to substation applications. These common data classes are used in IEC 61850-7-4. To define compatible data classes, the attributes of the instances of data shall be accessed using services defined in IEC 61850-7-2.

This part is used to specify the **abstract common data class** definitions. These abstract definitions shall be mapped into concrete object definitions that are to be used for a particular protocol (for example MMS, ISO 9506).

Compared to the published edition 1, this edition 2 of this standard:

- Defines new common data classes used for new standards defining object models for other domains based on IEC 61850 and for the representation of statistical and historical data.
- Provides clarifications and corrections to the published edition 1 of IEC 61850-7-3. Issues that require clarification are published in a database at www.tissue.iec61850.com.

This CD is based on Amendment 1 to IEC 61850-7-3, Ed 1 that has been circulated as 57/779/CD. Compared to the Amendment 1, this CD provides additional clarifications and it includes the following modifications:

- An extension of the CDC Nameplate as decided at the meeting in Charlotte in December 2005
- For the curve shape description, an option has been added to represent a curve in a three-dimensional space.
- A new CDC CSG to support the setting of a curve shape.
- A new CDC HST for histograms used in the power quality logical nodes.
- A new CDC TSG for time settings.

The numbering of figures and tables has been chosen such that the numbers from the first Edition remain the same. This helps to compare with the old document and since IEC has introduced manual numbering during the final editing of Edition 1, it helps to avoid introducing errors with references to figures and tables. For the publishing of the standard, the numbers will be updated.

Deleted: ¶

COMMUNICATION NETWORKS AND SYSTEMS FOR UTILITY AUTOMATION

Deleted: IN SUBSTATIONS

Part 7-3: Basic communication structure – Common data classes

Deleted: for substation and feeder equipment

1 Scope

This part of IEC 61850 specifies common attribute types and common data classes related to substation applications. In particular it specifies:

- common data classes for **status information**,
- common data classes for **measured information**,
- common data classes for **control**,
- common data classes for **status settings**,
- common data classes for **analogue settings** and
- **attribute types** used in these common data classes.

Comment [CB1]: TISSUE #28

Deleted: lable status information

Deleted: <#>common data classes for **controllable analogue set point information**,¶

This international standard is applicable to the description of device models and functions of substations and feeder equipment.

This international standard may also be applied, for example, to describe device models and functions for:

- substation to substation information exchange,
- substation to control centre information exchange,
- power plant to control centre information exchange,
- information exchange for distributed generation, or
- information exchange for metering.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 61850-2, *Communication networks and systems in substations – Part 2: Glossary*,

Deleted: 3

IEC 61850-7-1, *Communication networks and systems in substations – Part 7-1: Basic communication structure for substation and feeder equipment – Principles and models*

IEC 61850-7-2, *Communication networks and systems in substations – Part 7-2: Basic communication structure for substation and feeder equipment – Abstract communication service interface (ACSI)*

IEC 61850-7-4, *Communication networks and systems in substations – Part 7-4: Basic communication structure for substation and feeder equipment – Compatible logical node classes and data classes*

ISO 1000, *SI units and recommendations for the use of their multiples and of certain other units*

3 Terms and definitions

For the purposes of this International Standard, the terms and definitions given in IEC 61850-2 and 61850-7-2 apply.

Deleted: 4

Draft CD – R1.00

4 Abbreviated terms

CDC	Common Data Class
dchg	Trigger option for data-change
dupd	Trigger option for data-update
FC	Functional Constraint
qchg	Trigger option for quality-change
TrgOp	trigger option

NOTE Abbreviations used for the identification of the common data classes and as names of the attributes are specified in the specific Clauses of this document and are not repeated here.

5 Conditions for attribute inclusion

This Clause lists general conditions that specify the presence of an attribute.

Abbreviation	Condition
M	Attribute is mandatory.
O	Attribute is optional.
PICS_SUBST	Attribute is mandatory, if substitution is supported (for substitution, see IEC 61850-7-2).
GC_1	At least one of the attributes shall be present for a given instance of DATA.
GC_2 (n)	All or none of the data attributes belonging to the same group (n) shall be present for a given instance of DATA.
GC_CON	A configuration data attribute shall only be present, if the (optional) specific data attributes to which this configuration relates, is also present.
AC_LNO_M	The attribute shall be present if the data NamPIt belongs to LLNO; otherwise it may be optional.
AC_LNO_EX	The attribute shall be present only if the data NamPIt belongs to LLNO (applies to IdNs in CDC LPL only).
AC_DLD_M	The attribute shall be present, if LN name space of this LN deviates from the LN name space referenced by IdNs of the logical device in which this LN is contained (applies to InNs in CDC LPL only).
AC_DLN_M	The attribute shall be present, if data name space of this data deviates from the data name space referenced by either InNs of the logical node in which the data is contained or IdNs of the logical device in which the data is contained (applies to dataNs in all CDCs only).
AC_DLNDA_M	The attribute shall be present, if CDC name space of this data deviates from the CDC name space referenced by either the dataNs of the data, the InNs of the logical node in which the data is defined or IdNs of the logical device in which the data is contained (applies to cdcNs and cdcName in all CDCs only).
AC_SCAV	The presence of the configuration data attribute depends on the presence of i and f of the Analog Value of the data attribute to which this configuration attribute relates. For a given data object, that attribute 1) shall be present, if both i and f are present, 2) shall be optional if only i is present and 3) is not required if only f is present NOTE If only i is present in a device without floating point capabilities, the configuration parameter may be exchanged offline.
AC_ST	The attribute is mandatory, if the controllable status class supports status information.
AC_CO_M	If the controllable status class supports control, this attribute is available and a mandatory attribute.
AC_CO_O	If the controllable status class supports control, this attribute is available and an optional attribute.
AC_SG_M	The attribute is mandatory, if this data shall be member of a setting group.
AC_SG_O	The attribute is optional, if this data shall be member of a setting group.

Comment [CB2]: TISSUE #161

Deleted: setting group is supported

Deleted: is supported

Abbreviation	Condition
AC_NSG_M	The attribute is mandatory, if this data shall be a setting outside a setting group.
AC_NSG_O	The attribute is optional, if this data shall be a setting outside a setting group.
AC_RMS_M	The attribute is mandatory when the harmonics reference type is rms.
AC_CLC_Q	The attribute shall be optional, when the calculation type (according to data ClcTyp) for this LN is Max fundamental or RMS fundamental. The attribute shall not be available, if ClcTyp is TRUE RMS

Deleted: setting group is not supported

Deleted: setting group is not supported

Comment [CB3]: TISSUE #270

6 Common data attribute types

6.1 General

Common data attribute types are defined for the use in common data classes (CDC) in Clause 7.

IEC 61850-7-1 provides an overview of all IEC 61850-7 documents (IEC 61850-7-2, IEC 61850-7-3, and IEC 61850-7-4). IEC 61850-7-1 also describes the basic notation used in IEC 61850-7-3 and the description of the relations between the IEC 61850-7 documents.

NOTE The common data attribute type "TimeStamp" is specified in IEC 61850-7-2.

6.2 Quality

6.2.1 Overview

Quality type shall be as defined in Table 1.

Table 1 – Quality

Quality Type Definition			
Attribute Name	Attribute Type	Value/Value Range	M/O/C
	PACKED LIST		
validity	CODED ENUM	good invalid reserved questionable	M
detailQual	PACKED LIST		M
overflow	BOOLEAN		M
outOfRange	BOOLEAN		M
badReference	BOOLEAN		M
oscillatory	BOOLEAN		M
failure	BOOLEAN		M
oldData	BOOLEAN		M
inconsistent	BOOLEAN		M
inaccurate	BOOLEAN		M
source	CODED ENUM	process substituted DEFAULT process	M
test	BOOLEAN	DEFAULT FALSE	M
operatorBlocked	BOOLEAN	DEFAULT FALSE	M

The DEFAULT value shall be applied, if the functionality of the related attribute is not supported. The mapping may specify to exclude the attribute from the message, if it is not supported or if the DEFAULT value applies.

Quality shall be an attribute that contains information on the quality of the information from the server. The different quality identifiers are not independent. Basically, there are the following quality identifiers:

- validity;
- detail quality;
- source;
- test;
- blocked by operator.

NOTE The quality, as used within the scope of 61850, is related to the quality of the information from the **server**. There may be a requirement that the client uses additional quality information within its local database. This is a local issue and not part of the scope of IEC 61850. However, the quality of a client may have an impact on the quality supplied by a server of a client – server relationship at a higher level (see Figure 3).

6.2.2 Validity

Validity shall be good, questionable or invalid.

good: The value shall be marked good if no abnormal condition of the acquisition function or the information source is detected.

invalid: The value shall be marked invalid when an abnormal condition of the acquisition function or the information source (missing or non-operating updating devices) is detected. The value shall not be defined under this condition. The mark invalid shall be used to indicate to the client that the value may be incorrect and shall not be used.

EXAMPLE If an input unit detects an oscillation of one input it will mark the related information as invalid.

questionable: The value shall be marked questionable if a supervision function detects an abnormal behaviour, however the value could still be valid. The client shall be responsible for determining whether or not values marked "questionable" should be used.

6.2.3 Detail quality

The reason for an invalid or questionable value of an attribute may be specified in more detail with further quality identifiers. If one of these identifiers is set then validity shall be set to invalid or questionable. The following Table shows the relation of the detailed quality identifiers with invalid or questionable quality.

<i>DetailQual</i>	Invalid	Questionable
Overflow	X	
Out of Range	X	X
Bad Reference	X	X
Oscillatory	X	X
Failure	X	
Old data		X
Inconsistent		X
Inaccurate		X

overflow: this identifier shall indicate a quality issue that the value of the attribute to which the quality has been associated is beyond the capability of being represented properly (used for measurand information only).

EXAMPLE A measured value may exceed the range that may be represented by the selected data type, for example the data type is a 16-bit unsigned integer and the value exceeds 65535.

outOfRange: this identifier shall indicate a quality issue that the attribute to which the quality has been associated is beyond a predefined range of values. The server shall decide if validity shall be set to invalid or questionable (used for measurand information only).

EXAMPLE A measured value may exceed a predefined range, however the selected data type can still represent the value, for example the data type is a 16-bit unsigned integer, the predefined range is 0 to 40 000, if the value is between 40001 and 65535 it is considered to be out of range.

badReference: this identifier shall indicate that the value may not be a correct value due to a reference being out of calibration. The server shall decide if validity shall be set to invalid or questionable (used for measurand information and binary counter information only).

oscillatory: to prevent overloading of event driven communication channels, it is desirable to detect and suppress oscillating (fast changing) binary inputs. If a signal changes in a defined time (t_{osc}) twice in the same direction (from 0 to 1 or from 1 to 0) then it shall be defined as an oscillation and the detail quality identifier "oscillatory" shall be set. If a configured numbers of transient changes is detected, they shall be suppressed. In this time, the validity status "questionable" shall be set. If the signal is still in the oscillating state after the defined number of changes, the value shall be left in the state it was in when the oscillatory flag was set. In this case, the validity status "questionable" shall be reset and "invalid" shall be set as long as the signal is oscillating. If the configuration is such that all transient changes should be suppressed, the validity status "invalid" shall be set immediately in addition to the detail quality identifier "oscillatory" (used for status information only).

failure: this identifier shall indicate that a supervision function has detected an internal or external failure.

oldData: a value shall be oldData if an update is not made during a specific time interval. The value may be an old value that may have changed in the meantime. This specific time interval may be defined by an allowed-age attribute.

NOTE "Fail silent" errors, where the equipment stops sending data will cause a oldData condition. In this case, the last received information was correct.

inconsistent: this identifier shall indicate that an evaluation function has detected an inconsistency.

inaccurate: this identifier shall indicate that the value does not meet the stated accuracy of the source.

EXAMPLE The measured value of power factor may be noisy (inaccurate) when the current is very small.

6.2.4 Source

Source shall give information related to the origin of a value. The value may be acquired from the process or be a substituted value.

process: the value is provided by an input function from the process I/O or is calculated from some application function.

substituted: the value is provided by input of an operator or by an automatic source.

NOTE 1 Substitution may be done locally or via the communication services. In the second case, specific attributes with a FC SV are used.

NOTE 2 There are various means to clear a substitution. As an example, a substitution that was done following an invalid condition may be cleared automatically if the invalid condition is cleared. However, this is a local issue and therefore not in the scope of this standard.

6.2.5 Test

Test shall be an additional identifier that may be used to classify a value being a test value and not to be used for operational purposes. The processing of the test quality in the client shall be a local issue. The bit shall be completely independent from the other bits within the quality descriptor.

The test identifier should normally be propagated through all hierarchical levels.

6.2.6 Blocked by operator

operatorBlocked: this identifier shall be set if further update of the value has been blocked by an operator. The value shall be the information that was acquired before blocking. If this identifier is set then the identifier `oldData` of `detailQual` shall also be set.

NOTE Both an operator as well as an automatic function may block communication updating as well as input updating. In both cases, `detailQual.oldData` will be set. If the blocking is done by an operator, then the identifier `operatorBlocked` is set additionally. In that case, an operator activity is required to clear the condition.

EXAMPLE An operator may block the update of an input, to save the old value, if the auxiliary supply is switched off.

6.2.7 Quality in the client server context




Figure 1 – Quality identifiers in a single client – server relationship

The quality identifier shall reflect the quality of the information in the server, as it is supplied to the client. Figure 1 shows potential sources that may influence the quality in a single client – server relationship. "Information Source" is the (hardwired) connection of the process information to the system. The information may be invalid or questionable as indicated in Figure 1. Further abnormal behaviour of the information source may be detected by the input unit. In that case, the input unit may keep the old data and flag it accordingly.

In a multiple client - server relationship, as shown in Figure 2, information may be acquired over a communication link (with Client B). If that communication link is broken, client B will detect that error situation and qualify the information as questionable/old data.




Figure 2 – Quality identifiers in a multiple client – server relationship

In the multiple client-server relationship, the quality of the data received from server A shall reflect both the quality of the server B (acquired with client B) as well as its own quality. Therefore, handling of prioritisation of quality from different levels may require further specification beyond that included in this standard. For the identifier **validity**, the value **invalid** shall dominate over the value **questionable**, since this is the worst case. For the identifier **source**, the higher level of the multiple client – server relationship shall dominate over the lower level.

EXAMPLE Let A be the higher level and B the lower level. The quality from server B is invalid. If now the communication fails (questionable, oldData) between server B and client B, the quality will remain invalid and not become questionable, since the last information was not correct. Server A therefore will report the information as invalid.

6.2.8 Relation between quality identifiers

Validity and **source** have a prioritised relation. If **source** is in the “process” state, then **validity** shall determine the quality of the origin value. If **source** is in the “substitute” state, then **validity** shall be overruled by the definition of the substituted value. This is an important feature, since substitution is used to replace invalid values with substituted values that may be used by the client such as good values.

EXAMPLE 1 If both **questionable** and **substituted** are set, this means that the substituted value is questionable. This may happen if, in a hierarchical configuration, a substitution is performed at the lowest level and the communication fails on a higher level.

EXAMPLE 2 If an invalid value is substituted, the invalid field will be cleared and the substituted field will be set to indicate the substitution.

The quality identifier **operatorBlocked** is independent of the other quality identifiers.

EXAMPLE 3 An oscillating input may cause the **invalid** field to be set. Due to the continuing changes in the value many reports are generated, loading the communication network. An operator may block the update of the input. In this case the field **operatorBlocked** will also be set.

An example for the interaction between the quality identifiers and the impact of multiple client – server relation is shown in Figure 3. In this example, it is assumed that a bay level device acts as a client of the process level server and as a server to the station level client.

NOTE This is one example of a multiple client – server relationship; other multiple client - server relationships may exist, but the behaviour will not change.

In case A, the input is blocked, the quality of the information is marked as **questionable** and **oldData**.

In case B, a substitution is done at process level. Now, the quality of the information to the next higher level (the bay level) is marked as **substituted** (but good).

In case C, the communication between process and bay level fails. Between bay level and station level, the information is still marked as substituted. In addition, questionable and oldData is set to indicate that the (substituted) information may be old.

In case D, a new substitution is made at bay level. Now the quality of the information to the next higher level is marked as substituted (and good) and is independent from the first substitution.




Figure 3 – Interaction of substitution and validity

6.3 Analogue value

Analogue value type shall be as defined in Table 2.

Table 2 – Analogue value

AnalogueValue Type Definition			
Attribute Name	Attribute Type	Value/Value Range	M/O/C
<i>i</i>	INT32	integer value	GC_1
<i>f</i>	FLOAT32	floating point value	GC_1

Analogue values may be represented as a basic data type INTEGER (attribute *i*) or as FLOATING POINT (attribute *f*). At least one of the attributes shall be used. If both *i* and *f* exist, the application has to insure that both values remain consistent. The latest value set by the communication service shall be used to update the other value. As an example, if xxx.f is written, the application shall update xxx.i accordingly.

i: The value of *i* shall be an integer representation of the measured value. The formula to convert between *i* and *f* shall be:

$$f \times 10^{\text{units.multiplier}} = (i \times \text{scaleFactor}) + \text{offset}$$

It shall be true within acceptable error when *i*, scaleFactor, offset and *f* are all present.

f: The value of *f* shall be the floating point representation of the measured value. *f* shall represent the technological value.

NOTE The reason for both integer and floating point representation is so that IEDs without FLOATING POINT capabilities shall be enabled to support analogue values. In this case, the scaleFactor and offset may be exchanged offline between clients and servers.

6.4 Configuration of analogue value

Configuration of analogue value type shall be as defined in Table 3.

Table 3 – Configuration of analogue value

ScaledValueConfig Type Definition			
Attribute Name	Attribute Type	Value/Value Range	M/O/C
scaleFactor	FLOAT32		M
offset	FLOAT32		M

This data attribute type shall be used to configure the INTEGER value representation of the analogue value. The formula for conversion between integer and floating point value is given in 6.3.

scaleFactor: the value of scaleFactor shall be the scaling factor.

offset: the value of offset shall be the offset.

6.5 Range configuration

Range configuration type is used to configure the limits that define the range of a measured value and shall be as defined in Table 4.

Table 4 – Range configuration

RangeConfig Type Definition			
Attribute Name	Attribute Type	Value/Value Range	M/O/C
hhLim	AnalogueValue		M
hLim	AnalogueValue		M
lLim	AnalogueValue		M
llLim	AnalogueValue		M
min	AnalogueValue		M
max	AnalogueValue		M
limDb	INT32U	0 ... 100 000	0

Comment [CB4]: TISSUE #164

Formatted: TABLE-cell, Space Before: 0 pt, After: 0 pt

hhLim, hLim, lLim, llLim: These attributes shall be the configuration parameters used in the context with the range attribute as defined in clause 8.

min: the min (minimum) attribute shall represent the minimum process measurement for which values of *i* or *f* are considered within process limits. If the value is lower, q shall be set accordingly (validity = questionable, detailQual = outOfRange).

max: the max (maximum) attribute shall represent the maximum process measurement for which values of *i* or *f* are considered within process limits. If the value is higher, q shall be set accordingly (validity = questionable, detailQual = outOfRange).

limDb: The value is used to introduce a hysteresis in the calculation of range. Range is immediately set to the higher value, when a high limit has been crossed (to the lower value, when a low limit has been crossed). However, range is only set back to the lower value, when the value of the high limit minus limDb has been crossed (to the higher value when the value of the low limit plus limDb has been crossed). The value shall represent the percentage between max and min in units of 0.001%. If limDb is not present, no hysteresis calculation is made.

6.6 Step position with transient indication

Step position with transient indication type is for example used to indicate the position of tap changers and shall be as defined in Table 5.

Table 5 – Step position with transient indication

ValWithTrans Type Definition			
Attribute Name	Attribute Type	Value/Value Range	M/O/C
posVal	INT8	-64 ... 63	M
transInd	BOOLEAN		0

The **posVal** shall contain the step position, the **transInd** shall indicate that the equipment is in a transient state.

6.7 Pulse configuration

Pulse configuration type is used to configure the output pulse generated with a command and shall be as defined in Table 6.

Table 6 – Pulse configuration

PulseConfig Type Definition			
Attribute Name	Attribute Type	Value/Value Range	M/O/C
cmdQual	ENUMERATED	pulse persistent	M
onDur	INT32U		M
offDur	INT32U		M
numPls	INT32U		M

cmdQual: this identifier shall define if the control output is a pulse output or if it is a persistent output. If it is set to pulse, then the duration of the pulse shall be defined with the identifiers onDur, offDur and numPls. If it is set to persistent, the deactivation of the output pulse is a local issue determined in the server; as an example, when a switch controlled by this control output has reached the end position, the local control logic in the in the device implementing the server will deactivate the output.

onDur, offDur, numPls: as the result of receiving an **Operate** service, a pulsed output may be generated to the **on** or **off** input of a switching device. The shape of this output is defined by onDur, offDur and numPls according to Figure 4. NumPls shall specify the number of pulses that are generated. onDur shall specify the on duration of the pulse, offDur specifies the duration between two pulses. onDur and offDur shall be specified in ms; a value of 0 ms shall specify that the duration is locally defined.




Figure 4 – Configuration of command output pulse

6.8 Originator

Originator type shall be as defined in Table 7.

Table 7 – Originator

Originator Type Definition			
Attribute Name	Attribute Type	Value/Value Range	M/O/C
orCat	ENUMERATED	not-supported bay-control station-control remote-control automatic-bay automatic-station automatic-remote maintenance process	M
orIdent	OCTET STRING64		M

Originator shall contain information related to the originator of the last change of the data attribute representing the value of a controllable data.

Draft CD – R1.00

orCat: The originator category shall specify the category of the originator that caused a change of a value. An explanation of the values for orCat is given in Table 8.

Table 8 – Values for orCat

Value	Explanation
not-supported	orCat is not supported
bay-control	Control operation issued from an operator using a client located at bay level
station-control	Control operation issued from an operator using a client located at station level
remote-control	Control operation from a remote operator outside the substation (for example network control center)
automatic-bay	Control operation issued from an automatic function at bay level
automatic-station	Control operation issued from an automatic function at station level
automatic-remote	Control operation issued from a automatic function outside of the substation
maintenance	Control operation issued from a maintenance/service tool
process	Status change occurred without control action (for example external trip of a circuit breaker or failure inside the breaker)

orIdent: the originator identification shall show the address of the originator who caused the change of the value. The value of NULL shall be reserved to indicate that the originator of a particular action is not known or is not reported.

NOTE The type of address stored (application address, IP address, link address, ...) is whatever the server can detect. This may depend on the specific mapping

6.9 Unit definition

Unit type shall be as defined in Table 9.

Table 9 – Unit

Unit Type Definition			
Attribute Name	Attribute Type	Value/Value Range	M/O/C
SIUnit	ENUMERATED	According to Tables A.1 to A.4 in Annex A	M
multiplier	ENUMERATED	According to Table A.5 in Annex A	O

SIUnit: shall define the SI unit according to Annex A.

multiplier: shall define the multiplier value according to Annex A. The default value is 0 (i.e. multiplier = 1).

6.10 Vector definition

Vector type shall be as defined in Table 10.

Table 10 – Vector

Vector Type Definition			
Attribute Name	Attribute Type	Value/Value Range	M/O/C
mag	AnalogueValue		M
ang	AnalogueValue	-180 ... +180	AC CLC O

Comment [CB5]: WG Meeting Seoul

Comment [CB6]: TISSUE #270

Deleted: 0

mag: the magnitude of the complex value.

ang: the angle of the complex value. The unit is degrees. The angle reference is defined in the context where the Vector type is used.

6.11 Point definition

Point type shall be as defined in table 11.

Table 11 – Point

<u>Point</u> Type Definition			
Attribute Name	Attribute Type	Value/Value Range	M/O/C
xVal	FLOAT32		M
yVal	FLOAT32		M
<u>zVal</u>	<u>FLOAT32</u>		<u>0</u>

Comment [CB7]: TISSUE #58

Deleted: Vector

xVal: the x value of a curve point.

yVal: the y value of a curve point.

zVal: the z value of a curve point.

Comment [CB8]: TISSUE #54

Deleted: c

6.12 CtlModels definition

CtlModels type is defined as follows:

ENUMERATED (status-only | direct-with-normal-security | sbo-with-normal-security | direct-with-enhanced-security | sbo-with-enhanced-security)

6.13 SboClasses definition

SboClasses type is defined as follows:

ENUMERATED (operate-once | operate-many)

7 Common data class specifications

7.1 General

Common data classes are defined for use in part IEC 61850-7-4. Common data classes are composed of common data attribute types defined in Clause 6 of this part or of types defined in IEC 61850-7-2. IEC 61850-7-1 provides the basic notation used in this Clause.

The semantic of the DataAttributes (Data) is defined in clause 8.

Comment [CB9]: TISSUE #483

7.2 Name spaces

Name spaces are defined to specify extensions to the present definitions of IEC 61850-7-3 and IEC 61850-7-4. The name space is based on a hierarchical structure from logical node zero **LLN0** at the top down to the common data class **CDC**. See Table 12.

Table 12 – Name space attributes

Attribute	Application	Scope of the standard specified with the attribute
ldNs	The DATA-ATTRIBUTE ldNs shall be included in the logical node LLNO ↓	IEC 61850-7-4 (IEC 61850-7-3 by reference)
lnNs	The DATA-ATTRIBUTE lnNs shall be included if the name space of the LN deviates from the definition in the specification in which the LN is defined.	IEC 61850-7-4 (IEC 61850-7-3 by reference)
cdcNs	The DATA-ATTRIBUTE cdcNs shall be included if the definition of at least one DATA-ATTRIBUTE of the CDC deviates from the definition in the specification in which the CDC of the DATA is defined.	IEC 61850-7-3
dataNs	The DATA-ATTRIBUTE dataNs shall be included if the name space of the DATA deviates from the definition in the specification in which the LOGICAL-NODE and its DATA are defined.	IEC 61850-7-4 (IEC 61850-7-3 by reference)

Comment [CB10]: TISSUE #239

Deleted: if the name space of the logical device deviates from "IEC 61850-7-4: 2003"

7.3 Common data class specifications for status information

7.3.1 Application of services

Table 13 defines the basic status information template. In particular, it defines the inheritance and specialisation of services defined in IEC 61850-7-2.

Comment [CB11]: TISSUE #138

Deleted: Basic status information template

Table 13 – Basic status information template

Basic status information template					
Attribute Name	Attribute Type	FC	TrgOp	Value/Value Range	M/O/C
DataName	Inherited from Data Class (see IEC 61850-7-2)				
DataAttribute					
<i>status</i>					
<i>substitution</i>					
<i>configuration, description and extension</i>					
Services (see IEC 61850-7-2)					
The following services are inherited from IEC 61850-7-2. They are specialised by restricting the service to attributes with a functional constraint as specified below.					
Service model of IEC 61850-7-2	Service	Service applies to Attr with FC		Remark	
Data model	SetDataValues GetDataValues GetDataDefinition <u>GetDataDirectory</u>	DC, CF, SV ALL ALL <u>ALL</u>			
Data set model	GetDataSetValues DataSetValues	ALL DC, CF, SV			
Reporting model <u>GSE model</u>	Report <u>SendGOOSEMessage</u> <u>SendGSEMessage</u> <u>SendMSVMessage</u> <u>SendUSVMessage</u>	ALL <u>ST</u> <u>ST</u> <u>ST</u> <u>ST</u>		as specified within the data set that is used to define the content <u>of the message</u>	
<u>Sampled values model</u>					

Deleted: report

Comment [CB12]: TISSUE #60

7.3.2 Single point status (SPS)

Table 14 defines the common data class "single point status".

Table 14 – Single point status common data class definition

SPS class					
Attribute Name	Attribute Type	FC	TrgOp	Value/Value Range	M/O/C
DataName	Inherited from Data Class (see IEC 61850-7-2)				
DataAttribute					
<i>status</i>					
stVal	BOOLEAN	ST	dchg	TRUE FALSE	M
q	Quality	ST	qchg		M
t	TimeStamp	ST			M
<i>substitution</i>					
subEna	BOOLEAN	SV	dchg		PICS_SUBST
subVal	BOOLEAN	SV	dchg	TRUE FALSE	PICS_SUBST
subQ	Quality	SV	dchg		PICS_SUBST
subID	VISIBLE STRING64	SV	dchg		PICS_SUBST
<i>configuration, description and extension</i>					
d	VISIBLE STRING255	DC		Text	O
dU	UNICODE STRING255	DC			O
cdcNs	VISIBLE STRING255	EX			AC_DLNDA_M
cdcName	VISIBLE STRING255	EX			AC_DLNDA_M
dataNs	VISIBLE STRING255	EX			AC_DLN_M
Services					
As defined in Table 13					

Comment [CB13]: TISSUE #204

7.3.3 Double point status (DPS)

Table 15 defines the common data class “double point status”.

Table 15 – Double point status common data class specification

DPS class					
Attribute Name	Attribute Type	FC	TrgOp	Value/Value Range	M/O/C
DataName	Inherited from Data Class (see IEC 61850-7-2)				
DataAttribute					
<i>status</i>					
stVal	CODED ENUM	ST	dchg	intermediate-state off on bad-state	M
q	Quality	ST	qchg		M
t	TimeStamp	ST			M
<i>substitution</i>					
subEna	BOOLEAN	SV	dchg		PICS_SUBST
subVal	CODED ENUM	SV	dchg	intermediate-state off on bad-state	PICS_SUBST
subQ	Quality	SV	dchg		PICS_SUBST
subID	VISIBLE STRING64	SV	dchg		PICS_SUBST
<i>configuration, description and extension</i>					
d	VISIBLE STRING255	DC		Text	O
dU	UNICODE STRING255	DC			O
cdcNs	VISIBLE STRING255	EX			AC_DLNDA_M
cdcName	VISIBLE STRING255	EX			AC_DLNDA_M
dataNs	VISIBLE STRING255	EX			AC_DLN_M
Services					
As defined in Table 13					

7.3.4 Integer status (INS)

Table 16 defines the common data class “integer status”.

Table 16 – Integer status common data class specification

INS class					
Attribute Name	Attribute Type	FC	TrgOp	Value/Value Range	M/O/C
DataName	Inherited from Data Class (see IEC 61850-7-2)				
DataAttribute					
<i>status</i>					
stVal	CtxInt	ST	dchg		M
q	Quality	ST	qchg		M
t	TimeStamp	ST			M
<i>substitution</i>					
subEna	BOOLEAN	SV	dchg		PICS_SUBST
subVal	CtxInt	SV	dchg		PICS_SUBST
subQ	Quality	SV	dchg		PICS_SUBST
subID	VISIBLE STRING64	SV	dchg		PICS_SUBST
<i>configuration, description and extension</i>					
d	VISIBLE STRING255	DC		Text	O
dU	UNICODE STRING255	DC			O
cdcNs	VISIBLE STRING255	EX			AC_DLNDA_M
cdcName	VISIBLE STRING255	EX			AC_DLNDA_M
dataNs	VISIBLE STRING255	EX			AC_DLN_M
Services					
As defined in Table 13					

Comment [CB14]: TISSUE #171
Deleted: INT32

Comment [CB15]: TISSUE #171
Deleted: INT32

7.3.5 Protection activation information (ACT)

Table 17 defines the common data class “protection activation information”.

Table 17 – Protection activation information common data class specification

ACT class					
Attribute Name	Attribute Type	FC	TrgOp	Value/Value Range	M/O/C
DataName	Inherited from Data Class (see IEC 61850-7-2)				
DataAttribute					
<i>status</i>					
general	BOOLEAN	ST	dchg		M
phsA	BOOLEAN	ST	dchg		O
phsB	BOOLEAN	ST	dchg		O
phsC	BOOLEAN	ST	dchg		O
neut	BOOLEAN	ST	dchg		O
q	Quality	ST	qchg		M
t	TimeStamp	ST			M
origin	Originator	ST			O
operTmPhsA	TimeStamp	ST			O
operTmPhsB	TimeStamp	ST			O
operTmPhsC	TimeStamp	ST			O
<i>configuration, description and extension</i>					
d	VISIBLE STRING255	DC		Text	O
dU	UNICODE STRING255	DC			O
cdcNs	VISIBLE STRING255	EX			AC_DLNDA_M
cdcName	VISIBLE STRING255	EX			AC_DLNDA_M
dataNs	VISIBLE STRING255	EX			AC_DLN_M
Services					
As defined in Table 13					

Comment [CB16]: TISSUE #68

Comment [CB17]: TISSUE #219

Deleted: operTm [1]

NOTE – the attribute origin may be used to identify the originator when a data of the CDC ACT is used to perform an operation. An example would be the data OpOpn of the LN CSWI being used to open a breaker (LN XCBR) through a GOOSE message. The LN XCBR receives the data CSWI.OpOpn including the originator as a GOOSE message. Once operated, the new status information in XCBR.Pos will include the originator information it received as part of the GOOSE message that triggered the operation.

7.3.6 Directional protection activation information (ACD)

Table 18 defines the common data class “directional protection activation information”.

Table 18 – Directional protection activation information common data class specification

ACD class					
Attribute Name	Attribute Type	FC	TrgOp	Value/Value Range	M/O/C
DataName	Inherited from Data Class (see IEC 61850-7-2)				
DataAttribute					
<i>status</i>					
general	BOOLEAN	ST	dchg		M
dirGeneral	ENUMERATED	ST	dchg	unknown forward backward both	M
phsA	BOOLEAN	ST	dchg		GC_2 (1)
dirPhsA	ENUMERATED	ST	dchg	unknown forward backward	GC_2 (1)
phsB	BOOLEAN	ST	dchg		GC_2 (2)
dirPhsB	ENUMERATED	ST	dchg	unknown forward backward	GC_2 (2)
phsC	BOOLEAN	ST	dchg		GC_2 (3)
dirPhsC	ENUMERATED	ST	dchg	unknown forward backward	GC_2 (3)
neut	BOOLEAN	ST	dchg		GC_2 (4)
dirNeut	ENUMERATED	ST	dchg	unknown forward backward	GC_2 (4)
q	Quality	ST	qchg		M
t	TimeStamp	ST			M
<i>configuration, description and extension</i>					
d	VISIBLE STRING255	DC		Text	O
dU	UNICODE STRING255	DC			O
cdcNs	VISIBLE STRING255	EX			AC_DLNDA_M
cdcName	VISIBLE STRING255	EX			AC_DLNDA_M
dataNs	VISIBLE STRING255	EX			AC_DLN_M
Services					
As defined in Table 13					

7.3.7 Security violation counting (SEC)

Table 19 defines the common data class “security violation counting”.

Table 19 – Security violation counting common data class specification

SEC class					
Attribute Name	Attribute Type	FC	TrgOp	Value/Value Range	M/O/C
DataName	Inherited from Data Class (see IEC 61850-7-2)				
DataAttribute					
<i>status</i>					
cnt	INT32U	ST	dchg		M
sev	ENUMERATED	ST		unknown critical major minor warning	M
t	TimeStamp	ST			M
addr	OCTET STRING64	ST			O
addInfo	VISIBLE STRING64	ST			O
<i>configuration, description and extension</i>					
d	VISIBLE STRING255	DC		Text	O
dU	UNICODE STRING255	DC			O
cdcNs	VISIBLE STRING255	EX			AC_DLNDA_M
cdcName	VISIBLE STRING255	EX			AC_DLNDA_M
dataNs	VISIBLE STRING255	EX			AC_DLN_M
Services					
As defined in Table 13					

7.3.8 Binary counter reading (BCR)

Table 20 defines the common data class “binary counter reading”.

Table 20 – Binary counter reading common data class specification

BCR class					
Attribute Name	Attribute Type	FC	TrgOp	Value/Value Range	M/O/C
DataName	Inherited from Data Class (see IEC 61850-7-2)				
DataAttribute					
<i>status</i>					
actVal	INT128	ST	dchg		M
frVal	INT128	ST	dupd		GC_2 (1)
frTm	TimeStamp	ST	dupd		GC_2 (1)
q	Quality	ST	qchg		M
t	TimeStamp	ST			M
<i>configuration, description and extension</i>					
units	Unit	CF	dchg	see Annex A	O
pulsQty	FLOAT32	CF	dchg		M
frEna	BOOLEAN	CF	dchg		GC_2 (1)
strTm	TimeStamp	CF	dchg		GC_2 (1)
frPd	INT32	CF	dchg		GC_2 (1)
frRs	BOOLEAN	CF	dchg		GC_2 (1)
d	VISIBLE STRING255	DC			O
dU	UNICODE STRING255	DC			O
cdcNs	VISIBLE STRING255	EX			AC_DLNDA_M
cdcName	VISIBLE STRING255	EX			AC_DLNDA_M
dataNs	VISIBLE STRING255	EX			AC_DLN_M
Services					
As defined in Table 13					

7.3.9 **Histogram (HST)**

Comment [CB18]: Editor meeting Power Quality / Feb 2007

Table 20.1 defines the common data class "Histogram".

Table 20.1 – Histogram common data class specification

HST class					
Attribute Name	Attribute Type	FC	TrgOp	Value/Value Range	M/O/C
DataName	Inherited from Data Class (see IEC 61850-7-2)				
DataAttribute					
<i>status</i>					
numPts	INT16U	ST		>1	M
hstCnt	ARRAY 1..numPts OF INT32	ST	dchg, dupd		M
q	Quality	ST	gchg		M
t	TimeStamp	ST			M
<i>configuration, description and extension</i>					
hstRangeC	ARRAY 1..numPts OF AnalogueValue	CF	dchg		M
hstRangeUnits	Unit	CF	dchg		M
d	VISIBLE.STRING255	DC			Q
dU	UNICODE.STRING255	DC			Q
cdcNs	VISIBLE.STRING255	EX			AC_DLND M
cdcName	VISIBLE.STRING255	EX			AC_DLND M
dataNs	VISIBLE.STRING255	EX			AC_DLN M
Services					
As defined in Table 13					

Formatted: Not Highlight

Deleted: ¶

7.4 Common data class specifications for measurand information

7.4.1 **Application of services**

Table 21 defines the basic measurand information template. In particular, it defines the inheritance and specialisation of services defined in IEC 61850-7-2.

NOTE Measured values as used in the following clauses may also be applied to calculated values.

Table 21 – Basic measurand information template

Basic measurand information template					
Attribute Name	Attribute Type	FC	TrgOp	Value/Value Range	M/O/C
DataName	Inherited from Data Class (see IEC 61850-7-2)				
Data					
DataAttribute					
<i>measured attributes</i>					
<i>substitution</i>					
<i>configuration, description and extension</i>					
Services (see IEC 61850-7-2)					
The following services are inherited from IEC 61850-7-2. They are specialised by restricting the service to attributes with a functional constraint as specified below.					
Service model of IEC 61850-7-2	Service	Service applies to Attr with FC		Remark	
Data model	SetDataValues GetDataValues GetDataDefinition GetDataDirectory	DC, CF, SV ALL ALL ALL			
Data set model	GetDataSetValues SetDataSetValues	ALL DC, CF, SV			
Reporting model GSE model Sampled values model	Report SendGOOSEMessage SendMSVMessage SendUSVMessage	ALL MX MX MX		as specified within the data set that is used to define the content of the message	

Comment [CB19]: TISSUE #138

Deleted: Basic measurand information template

Comment [CB20]: TISSUE #483

Deleted: report

Comment [CB21]: TISSUE #60

7.4.2 Measured value (MV)

Table 22 defines the common data class “measured value”.

Table 22 – Measured value

MV class					
Attribute Name	Attribute Type	FC	TrgOp	Value/Value Range	M/O/C
DataName	Inherited from Data Class (see IEC 61850-7-2)				
DataAttribute					
<i>measured attributes</i>					
instMag	AnalogueValue	MX			O
mag	AnalogueValue	MX	dchg		M
range	ENUMERATED	MX	dchg	normal high low high-high low-low	O
q	Quality	MX	qchg		M
t	TimeStamp	MX			M
<i>substitution</i>					
subEna	BOOLEAN	SV	dchg		PICS_SUBST
subMag	AnalogueValue	SV	dchg		PICS_SUBST
subQ	Quality	SV	dchg		PICS_SUBST
subID	VISIBLE STRING64	SV	dchg		PICS_SUBST
<i>configuration, description and extension</i>					
units	Unit	CF	dchg	see Annex A	O
db	INT32U	CF	dchg	0 ... 100 000	O
zeroDb	INT32U	CF	dchg	0 ... 100 000	O
sVC	ScaledValueConfig	CF	dchg		AC_SCAV
rangeC	RangeConfig	CF	dchg		GC_CON
smpRate	INT32U	CF	dchg		O
d	VISIBLE STRING255	DC		Text	O
dU	UNICODE STRING255	DC			O
cdcNs	VISIBLE STRING255	EX			AC_DLNDA_M
cdcName	VISIBLE STRING255	EX			AC_DLNDA_M
dataNs	VISIBLE STRING255	EX			AC_DLN_M
Services					
As defined in Table 21					

Comment [CB22]: TISSUE #266

Deleted: |

Deleted: ...

7.4.3 Complex measured value (CMV)

Table 23 defines the common data class “complex measured value”.

Table 23 – Complex measured value

CMV class					
Attribute Name	Attribute Type	FC	TrgOp	Value/Value Range	M/O/C
DataName	Inherited from Data Class (see IEC 61850-7-2)				
DataAttribute					
<i>measured attributes</i>					
instCVal	Vector	MX			O
cVal	Vector	MX	dchg		M
range	ENUMERATED	MX	dchg	normal high low high-high low-low	O
rangeAng	ENUMERATED	MX	dchg	normal high low high-high low-low	O
q	Quality	MX	qchg		M
t	TimeStamp	MX			M
<i>substitution</i>					
subEna	BOOLEAN	SV	dchg		PICS_SUBST
subCVal	Vector	SV	dchg		PICS_SUBST
subQ	Quality	SV	dchg		PICS_SUBST
subID	VISIBLE STRING64	SV	dchg		PICS_SUBST
<i>configuration, description and extension</i>					
units	Unit	CF	dchg	see Annex A	O
db	INT32U	CF	dchg	0 ... 100 000	O
dbAng	INT32U	CF	dchg	0 ... 100 000	O
zeroDb	INT32U	CF	dchg	0 ... 100 000	O
rangeC	RangeConfig	CF	dchg		GC_CON
rangeAngC	RangeConfig	CF	dchg		GC_CON
magSVC	ScaledValueConfig	CF	dchg		AC_SCAV
angSVC	ScaledValueConfig	CF	dchg		AC_SCAV
angRef	ENUMERATED	CF	dchg	V A other ...	O
smpRate	INT32U	CF	dchg		O
d	VISIBLE STRING255	DC		Text	O
dU	UNICODE STRING255	DC			O
cdcNs	VISIBLE STRING255	EX			AC_DLNDA_M
cdcName	VISIBLE STRING255	EX			AC_DLNDA_M
dataNs	VISIBLE STRING255	EX			AC_DLN_M
Services					
As defined in Table 21					

Comment [CB23]: TISSUE #266

Deleted: |...

Comment [CB24]: TISSUE 482

Comment [CB25]: TISSUE 65; WG Meeting Seoul

7.4.4 Sampled value (SAV)

Table 24 defines the common data class “sampled value”. This common data class is used to represent samples of instantaneous analogue values. The values are usually transmitted using the "transmission of sampled value model" as defined in IEC 61850-7-2.

Table 24 – Sampled value

SAV class					
Attribute Name	Attribute Type	FC	TrgOp	Value/Value Range	M/O/C
DataName	Inherited from Data Class (see IEC 61850-7-2)				
DataAttribute					
<i>measured attributes</i>					
instMag	AnalogueValue	MX			M
q	Quality	MX	qchg		M
t	TimeStamp	MX			O
<i>configuration, description and extension</i>					
units	Unit	CF	dchg	see Annex A	O
sVC	ScaledValueConfig	CF	dchg		AC_SCAV
min	AnalogueValue	CF	dchg		O
max	AnalogueValue	CF	dchg		O
d	VISIBLE STRING255	DC		Text	O
dU	UNICODE STRING255	DC			O
cdcNs	VISIBLE STRING255	EX			AC_DLNDA_M
cdcName	VISIBLE STRING255	EX			AC_DLNDA_M
dataNs	VISIBLE STRING255	EX			AC_DLN_M
Services					
As defined in Table 21					

7.4.5 Phase to ground related measured values of a three phase system (WYE)

Table 25 defines the common data class “WYE”. This class is a collection of simultaneous measurements of values in a three phase system that represent phase to ground values.

Table 25 – WYE

WYE class					
Attribute Name	Attribute Type	FC	TrgOp	Value/Value Range	M/O/C
DataName	Inherited from Data Class (see IEC 61850-7-2)				
Data					
phsA	CMV				GC_1
phsB	CMV				GC_1
phsC	CMV				GC_1
neut	CMV				GC_1
net	CMV				GC_1
res	CMV				GC_1
DataAttribute					
<i>configuration, description and extension</i>					
angRef	ENUMERATED	CF	dchg	Va Vb Vc Aa Ab Ac Vab Vbc Vca Vother Aother	O
d	VISIBLE STRING255	DC		Text	O
dU	UNICODE STRING255	DC			O
cdcNs	VISIBLE STRING255	EX			AC_DLNDA_M
cdcName	VISIBLE STRING255	EX			AC_DLNDA_M
dataNs	VISIBLE STRING255	EX			AC_DLN_M
Services					
As defined in Table 21					

With regard to data attributes of the CDC CMV, the following additional specifications apply:

- The data attribute angRef of phsA, phsB, phsC, neut, net and res shall not be used. Instead, the attribute angRef defined with the CDC WYE shall be used.
- The values of phsA.t, phsB.t, phsC.t, neut.t, net.t and res.t are identical. They specify the time at which the values for phsA, phsB, phsC and neut have been simultaneously acquired or determined.

7.4.6 Phase to phase related measured values of a three phase system (DEL)

Table 26 defines the common data class “delta”. This class is a collection of measurements of values in a three phase system that represent phase to phase values.

Table 26 – Delta

DEL class					
Attribute Name	Attribute Type	FC	TrgOp	Value/Value Range	M/O/C
DataName	Inherited from Data Class (see IEC 61850-7-2)				
Data					
phsAB	CMV				GC_1
phsBC	CMV				GC_1
phsCA	CMV				GC_1
DataAttribute					
<i>configuration, description and extension</i>					
angRef	ENUMERATED	CF	dchg	Va Vb Vc Aa Ab Ac Vab Vbc Vca Vother Aother	O
d	VISIBLE STRING255	DC		Text	O
dU	UNICODE STRING255	DC			O
cdcNs	VISIBLE STRING255	EX			AC_DLNDA_M
cdcName	VISIBLE STRING255	EX			AC_DLNDA_M
dataNs	VISIBLE STRING255	EX			AC_DLN_M
Services					
As defined in Table 21					

With regard to data attributes of the CDC CMV, the following additional specifications apply:

- The data attribute angRef of phsAB, phsBC and phsCA shall not be used. Instead, the attribute angRef defined with the CDC DEL shall be used.
- The values of phsAB.t, phsBC.t and phsCA.t are identical. They specify the time at which the values for phsAB, phsBC and phsCA have been simultaneously acquired or determined.

7.4.7 Sequence (SEQ)

Table 27 defines the common data class “sequence”. This class is a collection of sequence components of a value.

Table 27 – Sequence

SEQ class					
Attribute Name	Attribute Type	FC	TrgOp	Value/Value Range	M/O/C
DataName	Inherited from Data Class (see IEC 61850-7-2)				
Data					
c1	CMV				M
c2	CMV				M
c3	CMV				M
DataAttribute					
<i>measured attributes</i>					
seqT	ENUMERATED	MX		pos-neg-zero dir-quad-zero	M
<i>configuration, description and extension</i>					
phsRef	ENUMERATED	CF	dchg	A B C ...	O
d	VISIBLE STRING255	DC		Text	O
dU	UNICODE STRING255	DC			O
cdcNs	VISIBLE STRING255	EX			AC_DLNDA_M
cdcName	VISIBLE STRING255	EX			AC_DLNDA_M
dataNs	VISIBLE STRING255	EX			AC_DLN_M
Services					
As defined in Table 21					

With regard to data attributes of the CDC CMV, the following additional specifications apply:

- The values of c1.t, c2.t and c3.t are identical. They specify the time at which the values for c1, c2 and c3 have been calculated.

7.4.8 Harmonic Value (HMV)

Table 28 defines the common data class for non phase related harmonic values. This class is a collection of values that represent the harmonic or interharmonic content of a process value.

Table 28 – Harmonic value

HMV class					
Attribute Name	Attribute Type	FC	TrgOp	Value/Value Range	M/O/C
DataName	Inherited from Data Class (see IEC 61850-7-2)				
Data					
har	ARRAY 0..numHar OF CMV				M
DataAttribute					
<i>configuration, description and extension</i>					
numHar	INT16U	CF	dchg	>0	M
numCyc	INT16U	CF	dchg	>0	M
evalTm	INT16U	CF	dchg		M
smpRate	INT32U	CF	dchg		O
frequency	FLOAT32	CF	dchg	nominal frequency	M
hvRef	ENUMERATED	CF	dchg	fundamental rms absolute	O
rmsCyc	INT16U	CF	dchg		AC_RMS_M
d	VISIBLE STRING255	DC		Text	O
dU	UNICODE STRING255	DC			O
cdcNs	VISIBLE STRING255	EX			AC_DLNDA_M
cdcName	VISIBLE STRING255	EX			AC_DLNDA_M
dataNs	VISIBLE STRING255	EX			AC_DLN_M
Services					
As defined in Table 21					

Comment [CB26]: TISSUE #330

Deleted: measured at (... [2])

Deleted: units (... [3])

NOTE Harmonics for a single circuit have phase angles (optional) but need no reference for the angle (angRef), since by convention the reference is always the fundamental frequency (index 1).

7.4.9 Harmonic value for WYE (HWYE)

Table 29 defines the common data class “harmonic value for WYE”. This class is a collection of simultaneous measurements (or evaluations) of values that represent the harmonic or interharmonic content of a process value in a three phase system with phase to ground values.

Table 29 – Harmonic values for WYE

HWYE class					
Attribute Name	Attribute Type	FC	TrgOp	Value/Value Range	M/O/C
DataName	Inherited from Data Class (see IEC 61850-7-2)				
Data					
<u>phsAHar</u>	<u>ARRAY 0..numHar OF CMV</u>				<u>M</u>
<u>phsBHar</u>	<u>ARRAY 0..numHar OF CMV</u>				<u>Q</u>
<u>phsCHar</u>	<u>ARRAY 0..numHar OF CMV</u>				<u>Q</u>
<u>neutHar</u>	<u>ARRAY 0..numHar OF CMV</u>				<u>Q</u>
<u>netHar</u>	<u>ARRAY 0..numHar OF CMV</u>				<u>Q</u>
<u>resHar</u>	<u>ARRAY 0..numHar OF CMV</u>				<u>Q</u>
DataAttribute					
<i>configuration, description and extension</i>					
numHar	INT16U	CF	<u>dchg</u>	>0	M
numCyc	INT16U	CF	<u>dchg</u>	>0	M
evalTm	INT16U	CF	<u>dchg</u>		M
angRef	ENUMERATED	CF	<u>dchg</u>	Va Vb Vc Aa Ab Ac Vab Vbc Vca Vother Aother	O
smpRate	INT32U	CF	<u>dchg</u>		O
frequency	FLOAT32	CF	<u>dchg</u>	fundamental frequency	M
hvRef	ENUMERATED	CF	<u>dchg</u>	fundamental rms absolute	O
rmsCyc	INT16U	CF	<u>dchg</u>		AC_RMS_M
d	VISIBLE STRING255	DC		Text	O
dU	UNICODE STRING255	DC			O
cdcNs	VISIBLE STRING255	EX			AC_DLNDA_M
cdcName	VISIBLE STRING255	EX			AC_DLNDA_M
dataNs	VISIBLE STRING255	EX			AC_DLN_M
Services					
As defined in Table 21					

Comment [CB27]: TISSUE #330

Deleted: measured at (... [4])

Deleted: units (... [5])

7.4.10 Harmonic value for DEL (HDEL)

Table 30 defines the common data class “harmonic value for delta”. This class is a collection of simultaneous measurements (or evaluations) of values that represent the harmonic or interharmonic content of a process value in a three phase system with phase to phase values.

Table 30 – Harmonic values for delta

HDEL class					
Attribute Name	Attribute Type	FC	TrgOp	Value/Value Range	M/O/C
DataName	Inherited from Data Class (see IEC 61850-7-2)				
Data					
phsABHar	ARRAY 0..numHar OF CMV				M
phsBCHar	ARRAY 0..numHar OF CMV				O
phsCAHar	ARRAY 0..numHar OF CMV				O
DataAttribute					
<i>configuration, description and extension</i>					
numHar	INT16U	CF	dchg	>0	M
numCyc	INT16U	CF	dchg	>0	M
evalTm	INT16U	CF	dchg		M
units	Unit	CF	dchg	see Annex A	O
angRef	ENUMERATED	CF	dchg	Va Vb Vc Aa Ab Ac Vab Vbc Vca Vother Aother	O
smpRate	INT32U	CF	dchg		O
frequency	FLOAT32	CF	dchg	nominal frequency	M
hvRef	ENUMERATED	CF	dchg	fundamental rms absolute	O
rmsCyc	INT16U	CF	dchg		AC_RMS_M
d	VISIBLE STRING255	DC		Text	O
dU	UNICODE STRING255	DC			O
cdcNs	VISIBLE STRING255	EX			AC_DLND_A_M
cdcName	VISIBLE STRING255	EX			AC_DLND_A_M
dataNs	VISIBLE STRING255	EX			AC_DLN_M
Services					
As defined in Table 21					

Comment [CB28]: TISSUE #330

Deleted: measured at (... [6])

7.5 Common data class specifications for control

Comment [CB29]: TISSUE #28

7.5.1 Application of services

Deleted: lable status information

Table 31 defines the basic controllable status information template. In particular, it defines the inheritance and specialisation of services defined in IEC 61850-7-2.

Table 31 – Basic controllable status information template

Basic controllable status information template					
Attribute Name	Attribute Type	FC	TrgOp	Value/Value Range	M/O/C
DataName	Inherited from Data Class (see IEC 61850-7-2)				
DataAttribute					
<i>status / measured attributes</i>					
<i>substitution</i>					
<i>configuration, description and extension</i>					
Services (see IEC 61850-7-2)					
<i>controllable parameters</i>					
The following services are inherited from IEC 61850-7-2. They are specialised by restricting the service to attributes with a functional constraint as specified below.					
Service model of IEC 61850-7-2	Service	Service applies to Attr with FC		Remark	
Data model	SetDataValues GetDataValues GetDataDefinition <u>GetDataDirectory</u>	DC, CF, SV ALL except CO ALL ALL			
Data set model	GetDataSetValues SetDataSetValues	ALL except CO DC, CF, SV			
Reporting model <u>GSE model</u>	Report <u>SendGOOSEMessage</u> <u>SendGSEMessage</u>	ALL <u>ST, MX</u> ST		as specified within the data set that is used to define the content of the message	
<u>Sampled values model</u>	<u>SendMSVMessage</u> <u>SendUSVMessage</u>	<u>ST, MX</u> ST, MX			
Control model	Select SelectWithValue Cancel Operate CommandTermination TimeActivatedOperate	CO CO CO CO CO CO CO			

Comment [CB30]: TISSUE #173

Comment [CB31]: TISSUE #28

Deleted: control and

Comment [CB32]: TISSUE #173

Deleted: report

Comment [CB33]: TISSUE #60

Comment [CB34]: WG10 Meeting Seoul

Comment [CB35]: TISSUE #56

Deleted: Synchroncheck

All common data classes for controllable status information include both the control and the related status information.

7.5.2 Controllable single point (SPC)

Table 32 defines the common data class “controllable single point”.

Table 32 – Controllable single point

SPC class					
Attribute Name	Attribute Type	FC	TrgOp	Value/Value Range	M/O/C
DataName	Inherited from Data Class (see IEC 61850-7-2)				
DataAttribute					
<i>status</i>					
origin	Originator	ST			AC_CO_O
ctINum	INT8U	ST		0..255	AC_CO_O
stVal	BOOLEAN	ST	dchg	FALSE TRUE	AC_ST
q	Quality	ST	qchg		AC_ST
t	TimeStamp	ST			AC_ST
stSeld	BOOLEAN	ST	dchg		AC_CO_O
<i>substitution</i>					
subEna	BOOLEAN	SV	dchg		PICS_SUBST
subVal	BOOLEAN	SV	dchg	FALSE TRUE	PICS_SUBST
subQ	Quality	SV	dchg		PICS_SUBST
subID	VISIBLE STRING64	SV	dchg		PICS_SUBST
<i>configuration, description and extension</i>					
pulseConfig	PulseConfig	CF	dchg		AC_CO_O
ctIModel	CtIModels	CF	dchg		M
sboTimeout	INT32U	CF	dchg		AC_CO_O
sboClass	SboClasses	CF	dchg		AC_CO_O
operTimeout	INT32U	CF	dchg		AC_CO_O
d	VISIBLE STRING255	DC		Text	O
dU	UNICODE STRING255	DC			O
cdcNs	VISIBLE STRING255	EX			AC_DLNDA_M
cdcName	VISIBLE STRING255	EX			AC_DLNDA_M
dataNs	VISIBLE STRING255	EX			AC_DLN_M
Services					
As defined in Table 31					
<i>controllable parameters</i>					
ctIVal	BOOLEAN	CO		off (FALSE) on (TRUE)	AC_CO_M
operTm	TimeStamp	CO			AC_CO_O
origin	Originator	CO			AC_CO_O
ctINum	INT8U	CO		0..255	AC_CO_O
I	TimeStamp	CO			M
Test	BOOLEAN	CO		No-test (FALSE) test (TRUE)	M
Check	PACKED LIST	CO			M
synchrocheck	BOOLEAN			Perform synchrocheck (TRUE)	
interlock-check	BOOLEAN			Check for interlocking conditions (TRUE)	

Comment [CB36]: TISSUE #173
 Deleted: control and
 Deleted: ctIVal ... [7]
 Deleted: CO,
 Deleted: CO,

Comment [CB37]: TISSUE #469

Comment [CB38]: TISSUE #173
 Formatted: Font: Italic

Comment [CB39]: TISSUE #35

Deleted: ¶

7.5.3 Controllable double point (DPC)

Table 33 defines the common data class “controllable double point”.

Table 33 – Controllable double point

DPC class					
Attribute Name	Attribute Type	FC	TrgOp	Value/Value Range	M/O/C
DataName	Inherited from Data Class (see IEC 61850-7-2)				
DataAttribute					
<i>status</i>					
origin	Originator	ST			AC_CO_O
ctINum	INT8U	ST		0..255	AC_CO_O
stVal	CODED ENUM	ST	dchg	intermediate-state off on bad-state	M
q	Quality	ST	qchg		M
t	TimeStamp	ST			M
stSeld	BOOLEAN	ST	dchg		AC_CO_O
<i>substitution</i>					
subEna	BOOLEAN	SV	dchg		PICS_SUBST
subVal	CODED ENUM	SV	dchg	intermediate-state off on bad-state	PICS_SUBST
subQ	Quality	SV	dchg		PICS_SUBST
subID	VISIBLE STRING64	SV	dchg		PICS_SUBST
<i>configuration, description and extension</i>					
pulseConfig	PulseConfig	CF	dchg		AC_CO_O
ctIModel	CtIModels	CF	dchg		M
sboTimeout	INT32U	CF	dchg		AC_CO_O
sboClass	SboClasses	CF	dchg		AC_CO_O
operTimeout	INT32U	CF	dchg		AC_CO_O
d	VISIBLE STRING255	DC		Text	O
dU	UNICODE STRING255	DC			O
cdcNs	VISIBLE STRING255	EX			AC_DLNDA_M
cdcName	VISIBLE STRING255	EX			AC_DLNDA_M
dataNs	VISIBLE STRING255	EX			AC_DLN_M
Services					
As defined in Table 31					
<i>controllable parameters</i>					
ctIVal	BOOLEAN	CO		off (FALSE) on (TRUE)	AC_CO_M
operTm	TimeStamp	CO			AC_CO_O
origin	Originator	CO			AC_CO_O
ctINum	INT8U	CO		0..255	AC_CO_O
I	TimeStamp	CO			M
Test	BOOLEAN	CO		No-test (FALSE) test (TRUE)	M
Check	PACKED LIST	CO			M
synchrocheck	BOOLEAN			Perform synchrocheck (TRUE)	
interlock-check	BOOLEAN			Check for interlocking conditions (TRUE)	

Deleted: control and
 Deleted: ctIVal ... [8]
 Deleted: CO,
 Deleted: CO,

Comment [CB40]: TISSUE #469

Comment [CB41]: TISSUE #173

Comment [CB42]: TISSUE #35

7.5.4 Controllable integer status (INC)

Table 34 defines the common data class “controllable integer status”.

Table 34 – Controllable integer status

INC class					
Attribute Name	Attribute Type	FC	TrgOp	Value/Value Range	M/O/C
DataName	Inherited from Data Class (see IEC 61850-7-2)				
DataAttribute					
<i>status</i>					
origin	Originator	ST			AC_CO_O
ctINum	INT8U	ST		0..255	AC_CO_O
stVal	CtxInt	ST	dchg		M
q	Quality	ST	qchg		M
t	TimeStamp	ST			M
stSeld	BOOLEAN	ST	dchg		AC_CO_O
<i>substitution</i>					
subEna	BOOLEAN	SV	dchg		PICS_SUBST
subVal	CtxInt	SV	dchg		PICS_SUBST
subQ	Quality	SV	dchg		PICS_SUBST
subID	VISIBLE STRING64	SV	dchg		PICS_SUBST
<i>configuration, description and extension</i>					
ctIModel	CTIModels	CF	dchg		M
sboTimeout	INT32U	CF	dchg		AC_CO_O
sboClass	SboClasses	CF	dchg		AC_CO_O
minVal	INT32	CF	dchg		O
maxVal	INT32	CF	dchg		O
stepSize	INT32U	CF	dchg	1 ... (maxVal – minVal)	O
operTimeout	INT32U	CF	dchg		AC_CO_O
d	VISIBLE STRING255	DC		Text	O
dU	UNICODE STRING255	DC			O
cdcNs	VISIBLE STRING255	EX			AC_DLNDA_M
cdcName	VISIBLE STRING255	EX			AC_DLNDA_M
dataNs	VISIBLE STRING255	EX			AC_DLN_M
Services					
As defined in Table 31					
<i>controllable parameters</i>					
ctIVal	CtxInt	CO			AC_CO_M
operTm	TimeStamp	CO			AC_CO_O
origin	Originator	CO			AC_CO_O
ctINum	INT8U	CO		0..255	AC_CO_O
I	TimeStamp	CO			M
Test	BOOLEAN	CO		No-test (FALSE) test (TRUE)	M
Check	PACKED LIST	CO			M
synchrocheck	BOOLEAN			Perform synchrocheck (TRUE)	
interlock-check	BOOLEAN			Check for interlocking conditions (TRUE)	

Deleted: control and

Deleted: ctIVal ... [9]

Deleted: CO,

Deleted: CO,

Comment [CB44]: TISSUE #171

Deleted: INT32

Comment [CB45]: TISSUE #171

Deleted: INT32

Comment [CB46]: TISSUE #469

Comment [CB47]: TISSUE #173

Comment [CB48]: TISSUE #35

7.5.5 Binary controlled step position information (BSC)

Table 35 defines the common data class “binary controlled step position information”.

Table 35 – Binary controlled step position information

BSC class					
Attribute Name	Attribute Type	FC	TrgOp	Value/Value Range	M/O/C
DataName	Inherited from Data Class (see IEC 61850-7-2)				
DataAttribute					
<i>status</i>					
origin	Originator	ST			AC_CO_O
ctINum	INT8U	ST		0..255	AC_CO_O
valWTr	ValWithTrans	ST	dchg		AC_ST
q	Quality	ST	qchg		AC_ST
t	TimeStamp	ST			AC_ST
stSeld	BOOLEAN	ST	dchg		AC_CO_O
<i>substitution</i>					
subEna	BOOLEAN	SV	dchg		PICS_SUBST
subVal	ValWithTrans	SV	dchg		PICS_SUBST
subQ	Quality	SV	dchg		PICS_SUBST
subID	VISIBLE STRING64	SV	dchg		PICS_SUBST
<i>configuration, description and extension</i>					
persistent	BOOLEAN	CF	dchg		M
ctIModel	CtIModels	CF	dchg		M
sboTimeout	INT32U	CF	dchg		AC_CO_O
sboClass	SboClasses	CF	dchg		AC_CO_O
minVal	INT8	CF	dchg		O
maxVal	INT8	CF	dchg		O
stepSize	INT8U	CF	dchg	1 ... (maxVal – minVal)	O
operTimeout	INT32U	CF	dchg		AC_CO_O
d	VISIBLE STRING255	DC		Text	O
dU	UNICODE STRING255	DC			O
cdcNs	VISIBLE STRING255	EX			AC_DLNDA_M
cdcName	VISIBLE STRING255	EX			AC_DLNDA_M
dataNs	VISIBLE STRING255	EX			AC_DLN_M
Services					
As defined in Table 31					
<i>controllable parameters</i>					
ctIVal	CODED ENUM	CO		stop lower higher reserved	AC_CO_M
operTm	TimeStamp	CO			AC_CO_O
origin	Originator	CO			AC_CO_O
ctINum	INT8U	CO		0..255	AC_CO_O
I	TimeStamp	CO			M
Test	BOOLEAN	CO		No-test (FALSE) test (TRUE)	M
Check	PACKED LIST	CO			M
synchrocheck	BOOLEAN			Perform synchrocheck (TRUE)	
interlock-check	BOOLEAN			Check for interlocking conditions (TRUE)	

Deleted: control and
 Deleted: ctIVal ... [10]
 Deleted: CO,
 Deleted: CO,

Comment [CB49]: TISSUE #469

Comment [CB50]: TISSUE #173

Comment [CB51]: TISSUE #35

7.5.6 Integer controlled step position information (ISC)

Table 36 defines the common data class “integer controlled step position information”.

Table 36 – Integer controlled step position information

ISC class					
Attribute Name	Attribute Type	FC	TrgOp	Value/Value Range	M/O/C
DataName	Inherited from Data Class (see IEC 61850-7-2)				
DataAttribute					
<i>status</i>					
origin	Originator	ST			AC_CO_O
ctlNum	INT8U	ST		0..255	AC_CO_O
valWTr	ValWithTrans	ST	dchg		AC_ST
q	Quality	ST	qchg		AC_ST
t	TimeStamp	ST			AC_ST
stSeld	BOOLEAN	ST	dchg		AC_CO_O
<i>substitution</i>					
subEna	BOOLEAN	SV	dchg		PICS_SUBST
subVal	ValWithTrans	SV	dchg		PICS_SUBST
subQ	Quality	SV	dchg		PICS_SUBST
subID	VISIBLE STRING64	SV	dchg		PICS_SUBST
<i>configuration, description and extension</i>					
ctlModel	CTIModels	CF	dchg		M
sboTimeout	INT32U	CF	dchg		AC_CO_O
sboClass	SboClasses	CF	dchg		AC_CO_O
minVal	INT8	CF	dchg		O
maxVal	INT8	CF	dchg		O
stepSize	INT8U	CF	dchg	1 ... (maxVal – minVal)	O
operTimeout	INT32U	CF	dchg		AC_CO_O
d	VISIBLE STRING255	DC		Text	O
dU	UNICODE STRING255	DC			O
cdcNs	VISIBLE STRING255	EX			AC_DLNDA_M
cdcName	VISIBLE STRING255	EX			AC_DLNDA_M
dataNs	VISIBLE STRING255	EX			AC_DLN_M
Services					
As defined in Table 31					
<i>controllable parameters</i>					
ctlVal	INT8	CO		-64 ... 63	AC CO M
operTm	TimeStamp	CO			AC CO O
origin	Originator	CO			AC CO O
ctlNum	INT8U	CO		0..255	AC CO O
I	TimeStamp	CO			M
Test	BOOLEAN	CO		No-test (FALSE) test (TRUE)	M
Check	PACKED LIST	CO			M
synchrocheck	BOOLEAN			Perform synchrocheck (TRUE)	
interlock-check	BOOLEAN			Check for interlocking conditions (TRUE)	

Deleted: control and
 Deleted: ctlVal ... [11]
 Deleted: CO,
 Deleted: CO,

Comment [CB52]: TISSUE #469

Comment [CB53]: TISSUE #173

Comment [CB54]: TISSUE #35

7.5.7 Controllable analogue process value (APC)

Comment [CB55]: TISSUE #28

Table 38 defines the common data class "controllable analogue process value".

Table 38– Controllable analogue process value

APC class					
Attribute Name	Attribute Type	FC	TrgOp	Value/Value Range	M/O/C
DataName	Inherited from Data Class (see IEC 61850-7-2)				
DataAttribute					
<i>measured attributes</i>					
origin	Originator	MX			Q
ctlNum	INT8U	SI		0..255	AC CO Q
mxVal	AnalogueValue	MX	dchg		Q
q	Quality	MX	qchg		M
t	TimeStamp	MX			M
stSeld	BOOLEAN	SI	dchg		AC CO Q
<i>configuration, description and extension</i>					
ctlModel	CTIModels	CF	dchg		M
sboTimeout	INT32U	CF	dchg		AC CO Q
sboClass	SboClasses	CF	dchg		AC CO Q
units	Unit	CF	dchg	see Annex A	Q
sVC	ScaledValueConfig	CF	dchg		AC SCAV
minVal	AnalogueValue	CF	dchg		Q
maxVal	AnalogueValue	CF	dchg		Q
stepSize	AnalogueValue	CF	dchg	0... (maxVal – minVal)	Q
operTimeout	INT32U	CF	dchg		AC CO Q
d	VISIBLE STRING255	DC		_Text	Q
dU	UNICODE STRING255	DC			Q
cdcNs	VISIBLE STRING255	EX			AC DLNDA M
cdcName	VISIBLE STRING255	EX			AC DLNDA M
dataNs	VISIBLE STRING255	EX			AC DLN M
Services					
As defined in Table 31					
<i>controllable parameters</i>					
ctlVal	AnalogueValue	CO			AC CO M
operTm	TimeStamp	CO			AC CO Q
origin	Originator	CO			AC CO Q
ctlNum	INT8U	CO		0..255	AC CO Q
t	TimeStamp	CO			M
Test	BOOLEAN	CO		No-test (FALSE) test (TRUE)	M
Check	PACKED LIST	CO			M
synchrocheck	BOOLEAN			Perform synchrocheck (TRUE)	
interlock-check	BOOLEAN			Check for interlocking conditions (TRUE)	

Comment [CB56]: TISSUE #469

Comment [CB57]: TISSUE #173

Formatted: Font: Italic

Formatted: Centered

Comment [CB58]: TISSUE #35

7.6 Common data class specifications for status settings

7.6.1 Application of services

Table 39 defines the basic controllable status settings template. In particular, it defines the inheritance and specialisation of services defined in IEC 61850-7-2.

Table 39 – Basic status setting template

Basic controllable status information template					
Attribute Name	Attribute Type	FC	TrgOp	Value/Value Range	M/O/C
DataName	Inherited from Data Class (see IEC 61850-7-2)				
DataAttribute					
<i>setting</i>					
<i>configuration, description and extension</i>					
Services (see IEC 61850-7-2)					
The following services are inherited from IEC 61850-7-2. They are specialised by restricting the service to attributes with a functional constraint as specified below.					
Service model of IEC 61850-7-2	Service	Service applies to Attr with FC		Remark	
Data model	SetDataValues GetDataValues GetDataDefinition GetDataDirectory	DC, CF, SP ALL ALL ALL			
Data set model	GetDataSetValues SetDataSetValues	ALL DC, CF			
Reporting model GSE model	Report SendGOOSEMessage	ALL SP		as specified within the data set that is used to define the content of the message	
Setting group control model	SetEditSGValues GetSGValues	SE SE, SG			

Deleted: <#>Common data class specifications for controllable analogue information¶
<#>Application of services¶
Table 37 defines the basic controllable analogue information template. In particular, it defines the inheritance and specialisation of services defined in IEC 61850-7-2.¶
Table 37 – Basic controllable analogue information template¶
Basic controllable analogue information template ... [12]

Comment [CB59]: TISSUE #60

Deleted: report

Comment [CB60]: WG10 Meeting Seoul

7.6.2 Single point setting (SPG)

Table 40 defines the common data class “single point setting”.

Table 40 – Single point setting

SPG class					
Attribute Name	Attribute Type	FC	TrgOp	Value/Value Range	M/O/C
DataName	Inherited from Data Class (see IEC 61850-7-2)				
DataAttribute					
<i>setting</i>					
setVal	BOOLEAN	SP	dchg	off (FALSE) on (TRUE)	AC_NSG_M
setVal	BOOLEAN	SG, SE		off (FALSE) on (TRUE)	AC_SG_M
<i>configuration, description and extension</i>					
d	VISIBLE STRING255	DC		Text	O
dU	UNICODE STRING255	DC			O
cdcNs	VISIBLE STRING255	EX			AC_DLNDA_M
cdcName	VISIBLE STRING255	EX			AC_DLNDA_M
dataNs	VISIBLE STRING255	EX			AC_DLN_M
Services					
As defined in Table 39					

Comment [CB61]: TISSUE #204

7.6.3 Integer status setting (ING)

Table 41 defines the common data class “integer status setting”.

Table 41 – Integer status setting

ING class					
Attribute Name	Attribute Type	FC	TrgOp	Value/Value Range	M/O/C
DataName	Inherited from Data Class (see IEC 61850-7-2)				
DataAttribute					
<i>setting</i>					
setVal	CtxInt	SP	dchg		AC_NSG_M
setVal	CtxInt	SG, SE			AC_SG_M
<i>configuration, description and extension</i>					
minVal	INT32	CF	dchg		O
maxVal	INT32	CF	dchg		O
stepSize	INT32U	CF	dchg	1 ... (maxVal – minVal)	O
d	VISIBLE STRING255	DC		Text	O
dU	UNICODE STRING255	DC			O
cdcNs	VISIBLE STRING255	EX			AC_DLNDA_M
cdcName	VISIBLE STRING255	EX			AC_DLNDA_M
dataNs	VISIBLE STRING255	EX			AC_DLN_M
Services					
As defined in Table 39					

Comment [CB62]: TISSUE #171

Deleted: INT32

Deleted: INT32

7.6.4 Object reference setting group (ORG)

Table 41.1 defines the common data class “object reference setting group”.

NOTE This common data class is used to specify the object reference to the logical node of which the statistical data have been calculated. This CDC shall be used, i.e., for the DATA CalcSrc to be included in the “Optional Logical Node Information” of the Common Logical Node defined in IEC 61850-7-4:2003. The conceptual model of the statistical data model is defined in the first amendment to IEC 61850-7-1:2003.

Table 41.1 – Object reference setting group common data class specification

ORG class					
Attribute Name	Attribute Type	FC	TrgOp	Value/Value Range	M/O/C
DataName	Inherited from Data Class (see IEC 61850-7-2)				
DataAttribute					
<i>Setting</i>					
setRef	VISIBLE STRING129	SP	dchg	Object Reference	AC_NSG_M
intAddr	VISIBLE STRING255	SP	dchg		AC_NSG_O
setRef	VISIBLE STRING129	SG, SE		Object Reference	AC_SG_M
intAddr	VISIBLE STRING255	SG, SE			AC_SG_O
<i>configuration, description and extension</i>					
d	VISIBLE STRING255	DC		Text	O
dU	UNICODE STRING255	DC			O
cdcNs	VISIBLE STRING255	EX			AC_DLNDA_M
cdcName	VISIBLE STRING255	EX			AC_DLNDA_M
dataNs	VISIBLE STRING255	EX			AC_DLN_M
Services					
As defined in Table 39					

Comment [CB63]: Statistics and historical

Comment [CB64]: TISSUE #216, 217

7.6.5 Time setting group (TSG)

Table 41.2 defines the common data class “Time setting group”.

Table 41.2 – Time setting group common data class specification

TSG class					
Attribute Name	Attribute Type	FC	TrgOp	Value/Value Range	M/O/C
DataName	Inherited from Data Class (see IEC 61850-7-2)				
DataAttribute					
<i>Setting</i>					
setTm	TimeStamp	SP	dchg	Object Reference	AC_NSG_M
setTm	TimeStamp	SG_SE		Object Reference	AC_SG_M
<i>configuration, description and extension</i>					
d	VISIBLE STRING255	DC		Text	O
dU	UNICODE STRING255	DC			O
cdcNs	VISIBLE STRING255	EX			AC_DLND M
cdcName	VISIBLE STRING255	EX			AC_DLND M
dataNs	VISIBLE STRING255	EX			AC_DLN M
Services					
As defined in Table 39					

7.7 Common data class specifications for analogue settings

7.7.1 Application of services

Table 42 defines the basic controllable analogue information template. In particular, it defines the inheritance and specialisation of services defined in IEC 61850-7-2.

Table 42 – Basic analogue setting template

Basic controllable analogue information template					
Attribute Name	Attribute Type	FC	TrgOp	Value/Value Range	M/O/C
DataName	Inherited from Data Class (see IEC 61850-7-2)				
DataAttribute					
<i>setting</i>					
<i>configuration, description and extension</i>					
Services (see IEC 61850-7-2)					
The following services are inherited from IEC 61850-7-2. They are specialised by restricting the service to attributes with a functional constraint as specified below.					
Service model of IEC 61850-7-2	Service	Service applies to Attr with FC		Remark	
Data model	SetDataValues GetDataValues GetDataDefinition <u>GetDataDirectory</u>	DC, CF, SP ALL ALL <u>ALL</u>			
Data set model	GetDataSetValues SetDataSetValues	ALL DC, CF			
Reporting model <u>GSE model</u> <u>Sampled values model</u>	Report <u>SendGOOSEMessage</u> <u>SendGSEMessage</u> <u>SendMSVMessage</u> <u>SendUSVMessage</u>	ALL		as specified within the data set that is used to define the content of the message	
Setting group control model	SetEditSGValues GetSGValues	SE SE, SG			

Deleted: report

Comment [CB65]: TISSUE #60

7.7.2 Analogue setting (ASG)

Table 43 defines the common data class "analogue setting".

Table 43 – Analogue setting

ASG class					
Attribute Name	Attribute Type	FC	TrgOp	Value/Value Range	M/O/C
DataName	Inherited from Data Class (see IEC 61850-7-2)				
DataAttribute					
<i>setting</i>					
setMag	AnalogueValue	SP	dchg		AC_NSg_M
setMag	AnalogueValue	SG, SE			AC_Sg_M
<i>configuration, description and extension</i>					
units	Unit	CF	dchg	see Annex A	O
sVC	ScaledValueConfig	CF	dchg		AC_SCAV
minVal	AnalogueValue	CF	dchg		O
maxVal	AnalogueValue	CF	dchg		O
stepSize	AnalogueValue	CF	dchg	0 ... (maxVal – minVal)	O
d	VISIBLE STRING255	DC		Text	O
dU	UNICODE STRING255	DC			O
cdcNs	VISIBLE STRING255	EX			AC_DLNDa_M
cdcName	VISIBLE STRING255	EX			AC_DLNDa_M
dataNs	VISIBLE STRING255	EX			AC_DLN_M
Services					
As defined in Table 42					

Comment [CB66]: TISSUE #439

Deleted: 1

7.7.3 Setting curve (CURVE)

Table 44 defines the common data class “setting curve”.

Table 44 – Setting curve

CURVE class					
Attribute Name	Attribute Type	FC	TrgOp	Value/Value Range	M/O/C
DataName	Inherited from Data Class (see IEC 61850-7-2)				
DataAttribute					
<i>setting</i>					
setCharact	ENUMERATED	SP	dchg		AC_NSNG_M
setParA	FLOAT32	SP	dchg		AC_NSNG_O
setParB	FLOAT32	SP	dchg		AC_NSNG_O
setParC	FLOAT32	SP	dchg		AC_NSNG_O
setParD	FLOAT32	SP	dchg		AC_NSNG_O
setParE	FLOAT32	SP	dchg		AC_NSNG_O
setParF	FLOAT32	SP	dchg		AC_NSNG_O
setCharact	ENUMERATED	SG, SE			AC_SG_M
setParA	FLOAT32	SG, SE			AC_SG_O
setParB	FLOAT32	SG, SE			AC_SG_O
setParC	FLOAT32	SG, SE			AC_SG_O
setParD	FLOAT32	SG, SE			AC_SG_O
setParE	FLOAT32	SG, SE			AC_SG_O
setParF	FLOAT32	SG, SE			AC_SG_O
<i>configuration, description and extension</i>					
d	VISIBLE STRING255	DC		Text	O
dU	UNICODE STRING255	DC			O
cdcNs	VISIBLE STRING255	EX			AC_DLNDA_M
cdcName	VISIBLE STRING255	EX			AC_DLNDA_M
dataNs	VISIBLE STRING255	EX			AC_DLN_M
Services					
As defined in Table 42					

Data of this common data class shall be used to describe setting curves used in protection equipment. The CDC CURVE is used to select with the attribute setChar one of up to 48 predefined curve shapes. In some cases, in addition, parameters may be changed for the curves. The curve shapes are typically defined with formulas that use up to 6 parameters. Some of these formulas are standardised (value of setCharact between 1 and 16), other formulas may be user defined (value of setCharact between 17 and 32; the specification of the formula is a local issue). In some cases, the curve may be specified as an array of n (x,y) pairs (value of setChar between 33 and 48; the specification of the array of n(x,y) pairs is a local issue; a data of the CDC CSG may be used to specify each of the characteristics 33 to 48). The resulting curve may be read from the device using a dedicated data of the CDC CSD as defined in 7.9.4.

Comment [CB67]: TISSUE #312

Comment [CB68]: Harmonization modelling workshop and discussions

7.7.4 Curve shape setting (CSG)

Table 44.1 defines the common data class for curve shape setting.

Table 44.1 – Curve shape setting

CSG class					
Attribute Name	Attribute Type	FC	TrgOp	Value/Value Range	M/O/C
DataName	Inherited from Data Class (see IEC 61850-7-2)				
DataAttribute					
<i>setting</i>					
pointZ	FLOAT32	SP			AC NSG O
xUnit	Unit	SP			AC NSG M
xD	VISIBLE STRING255	SP			AC NSG M
yUnit	Unit	SP			AC NSG M
yD	VISIBLE STRING255	SP			AC NSG M
numPts	INT16U	SP		≥1	AC NSG M
crvPts	ARRAY 1..numPts OF Point	SP			AC NSG M
pointZ	FLOAT32	SG_SE			AC SG O
xUnit	Unit	SG_SE			AC SG M
xD	VISIBLE STRING255	SG_SE			AC SG M
yUnit	Unit	SG_SE			AC SG M
yD	VISIBLE STRING255	SG_SE			AC SG M
numPts	INT16U	SG_SE		≥1	AC SG M
crvPts	ARRAY 1..numPts OF Point	SG_SE			AC SG M
<i>configuration, description and extension</i>					
d	VISIBLE STRING255	DC			M
dU	UNICODE STRING255	DC			Q
cdcNs	VISIBLE STRING255	EX			AC DLNDA M
cdcName	VISIBLE STRING255	EX			AC DLNDA M
dataNs	VISIBLE STRING255	EX			AC DLN M
Services					
As defined in Table 42					

The curve is created by the connection of crvPts[n] with crvPts[n+1] with 0<n<numPts. A three dimensional shape setting can be created by multiple instances of a data object with the CDC CSG. In that case, the attribute pointZ is used to represent the value of the curve on the z Axis. The three dimensional shape is created by connecting the curves with each other.

7.8 Common data class specifications for description information

7.8.1 Application of services

Table 45 defines the basic description information template. In particular, it defines the inheritance and specialisation of services defined in IEC 61850-7-2.

Comment [CB69]: TISSUE #138

Deleted: Basic description information template

Table 45 – Basic description information template

Basic description information template					
Attribute Name	Attribute Type	FC	TrgOp	Value/Value Range	M/O/C
DataName	Inherited from Data Class (see IEC 61850-7-2)				
DataAttribute					
<i>configuration, description and extension</i>					
Services (see IEC 61850-7-2)					
The following services are inherited from IEC 61850-7-2. They are specialised by restricting the service to attributes with a functional constraint as specified below.					
Service model of IEC 61850-7-2	Service	Service applies to Attr with FC		Remark	
Data model	SetDataValues GetDataValues GetDataDefinition GetDataDirectory	DC ALL ALL ALL			
Data set model	GetDataSetValues DataSetValues	ALL DC			
Reporting model	Report	ALL		as specified within the data set that is used to define the content of the message	

Deleted: report

7.8.2 Device name plate (DPL)

Table 46 defines the common data class “device name plate”. Data of this common data class are used to identify entities like primary equipment or physical devices.

Table 46 – Device name plate common data class specification

DPL class					
Attribute Name	Attribute Type	FC	TrgOp	Value/Value Range	M/O/C
DataName	Inherited from Data Class (see IEC 61850-7-2)				
DataAttribute					
<i>configuration, description and extension</i>					
vendor	VISIBLE STRING255	DC			M
hwRev	VISIBLE STRING255	DC			O
swRev	VISIBLE STRING255	DC			O
serNum	VISIBLE STRING255	DC			O
model	VISIBLE STRING255	DC			O
location	VISIBLE STRING255	DC			O
<u>owner</u>	<u>VISIBLE STRING255</u>	<u>DC</u>			<u>O</u>
<u>ePSName</u>	<u>VISIBLE STRING255</u>	<u>DC</u>			<u>O</u>
<u>role</u>	<u>VISIBLE STRING255</u>	<u>DC</u>			<u>O</u>
<u>primeOper</u>	<u>VISIBLE STRING255</u>	<u>DC</u>			<u>O</u>
<u>secondOper</u>	<u>VISIBLE STRING255</u>	<u>DC</u>			<u>O</u>
<u>latitude</u>	<u>FLOAT32</u>	<u>DC</u>			<u>O</u>
<u>longitude</u>	<u>FLOAT32</u>	<u>DC</u>			<u>O</u>
<u>altitude</u>	<u>FLOAT32</u>	<u>DC</u>			<u>O</u>
<u>tmOffset</u>	<u>INT16</u>	<u>DC</u>			<u>O</u>
<u>tmUseDT</u>	<u>BOOLEAN</u>	<u>DC</u>			<u>O</u>
<u>tmDT</u>	<u>BOOELAN</u>	<u>ST</u>			<u>O</u>
<u>d</u>	<u>VISIBLE STRING255</u>	<u>DC</u>			<u>O</u>
<u>dU</u>	<u>UNICODE STRING255</u>	<u>DC</u>			<u>O</u>
cdcNs	VISIBLE STRING255	EX			AC_DLNDA_M
cdcName	VISIBLE STRING255	EX			AC_DLNDA_M
dataNs	VISIBLE STRING255	EX			AC_DLN_M
Services					
As defined in Table 45					

Comment [CB70]: Harmonization with windpower and DER

Formatted: Not Highlight

Formatted: Not Highlight

Comment [CB71]: TISSUE #205

NOTE: the time related attributes are only of relevance for the physical name plate (not for the external equipment)

The change of the local time to daylight saving time can be a local issue. Optional, the change is possible through two settings: one with the UTC time of the next change to activate daylight saving time, one with the UTC time of the next change to deactivate daylight saving time.

7.8.3 Logical node name plate (LPL)

Table 47 defines the common data class “logical node name plate”. Data of this common data class are used to describe logical nodes.

Table 47 – Logical node name plate common data class specification

LPL class					
Attribute Name	Attribute Type	FC	TrgOp	Value/Value Range	M/O/C
DataName	Inherited from Data Class (see IEC 61850-7-2)				
DataAttribute					
<i>configuration, description and extension</i>					
vendor	VISIBLE STRING255	DC			M
swRev	VISIBLE STRING255	DC			M
d	VISIBLE STRING255	DC			M
dU	UNICODE STRING255	DC			O
configRev	VISIBLE STRING255	DC			AC_LN0_M
paramRev	VISIBLE STRING255	DC			O
valueRev	VISIBLE STRING255	DC			O
ldNs	VISIBLE STRING255	EX		shall be included in LLNO only; for example "IEC 61850-7-4:2003"	AC_LN0_EX
lnNs	VISIBLE STRING255	EX			AC_DLD_M
cdcNs	VISIBLE STRING255	EX			AC_DLNDA_M
cdcName	VISIBLE STRING255	EX			AC_DLNDA_M
dataNs	VISIBLE STRING255	EX			AC_DLN_M
Services					
As defined in Table 45					

Comment [CB72]: TISSUE #424

Comment [CB73]: TISSUE #424

7.8.4 Curve shape description (CSD)

Table 48 defines the common data class "curve shape description". Data of this common data class are used to read the shape of a curve as for example used with protection settings.

Table 48 – Curve shape description common data class specification

CSD class					
Attribute Name	Attribute Type	FC	TrgOp	Value/Value Range	M/O/C
DataName	Inherited from Data Class (see IEC 61850-7-2)				
DataAttribute					
<i>configuration, description and extension</i>					
xUnit	Unit	DC			M
xD	VISIBLE STRING255	DC			M
yUnit	Unit	DC			M
yD	VISIBLE STRING255	DC			M
zUnit	Unit	DC			O
zD	VISIBLE STRING255	DC			O
numPts	INT16U	DC		>1	M
crvPts	ARRAY<1..numPts> OF Point	DC			M
d	VISIBLE STRING255	DC			M
dU	UNICODE STRING255	DC			O
cdcNs	VISIBLE STRING255	EX			AC_DLNDA_M
cdcName	VISIBLE STRING255	EX			AC_DLNDA_M
dataNs	VISIBLE STRING255	EX			AC_DLN_M
Services					
As defined in Table 45					

Comment [CB74]: WG10 Meeting Seoul

Deleted: [

Deleted:]

The curve is created by the connection of crvPts[n] with crvPts[n+1] with 0<n<numPts.

8 Data attribute semantic

The data attributes, controllable parameters and in some case data used in Clause 7 shall have semantics as defined in Table 49.

Table 49 – Semantics of data attributes and data

Data attribute name	Semantics
actVal	Binary counter status represented as an integer value.
addInfo	Additional information that may give further clarification as to the last detected violation.
addr	Address of the remote source that last caused the count to be incremented. NOTE 1 The kind of address stored (application address, IP address, link address, ...) is whatever the server can detect. This may depend on the specific mapping.
<u>altitude</u>	<u>GPS position of device – altitude</u>
angRef	Angle reference. Indicates the quantity that is used as reference for the phase angle. For the indicated quantity, the fundamental frequency (index = 1) is used as reference by convention.
angSVC	Scaled value configuration for angles. Shall be used to configure the scaled value representation of the angle in a vector.
c1	Sequence component 1. For the semantic meaning see seqT.
c2	Sequence component 2. For the semantic meaning see seqT.
c3	Sequence component 3. For the semantic meaning see seqT.
cdcName	Name of the common data class. Used together with cdcNs, for details see IEC 61850-7-1.
cdcNs	Common data class name space. For details see IEC 61850-7-1.
<u>Check</u>	<u>The parameter Check shall specify the kind of checks a control object shall perform before issuing a control operation. The parameter is applicable for the following services:</u> <u>SeIVal (Request)</u> <u>Operate (Request)</u> <u>TimOper (Request)</u> <u>The parameter only needs to be considered if synchrocheck and interlock are used for the controlled item.</u>
cnt	Counter value of security violations.
configRev	Uniquely identifies the configuration of a logical device instance. ConfigRev in LLN0 (at LD level) has to be changed at least on any semantic change of the data model of this LD related to the client functionality. How this is detected and performed is left to the user. Also the semantics of configRev concerning other LNs is left to the user. <u>For further details see as well Annex C.</u>
crvPts	The array with the points specifying a curve shape

Comment [CB75]: TISSUE #173

Comment [CB76]: TISSUE #483

Deleted: 6 and

Comment [CB77]: TISSUE #483

Formatted: Not Highlight

Comment [CB78]: TISSUE #173

Comment [CB79]: WG10 meeting Seoul

Data attribute name	Semantics												
ctIModel	<p>Specifies the control model of IEC 61850-7-2 that corresponds to the behaviour of the data.</p> <table border="1" data-bbox="336 297 1046 582"> <thead> <tr> <th>Value</th> <th>Explanation</th> </tr> </thead> <tbody> <tr> <td>status-only</td> <td>The object is not controllable, only the services that apply to a status object are supported. The attribute ctIVal does not exist.</td> </tr> <tr> <td>direct-with-normal-security</td> <td>Direct control with normal security according to IEC 61850-7-2.</td> </tr> <tr> <td>sbo-with-normal-security</td> <td>SBO control with normal security according to IEC 61850-7-2.</td> </tr> <tr> <td>direct-with-enhanced-security</td> <td>Direct control with enhanced security according to IEC 61850-7-2.</td> </tr> <tr> <td>sbo-with-enhanced-security</td> <td>SBO control with enhanced security according to IEC 61850-7-2.</td> </tr> </tbody> </table> <p>NOTE 2 If a data instance of a control class has no status information associated, then the attribute stVal does not exist. In that case, the value range for ctIModel is restricted to direct-with-normal-security and sbo-with-normal-security.</p>	Value	Explanation	status-only	The object is not controllable, only the services that apply to a status object are supported. The attribute ctIVal does not exist.	direct-with-normal-security	Direct control with normal security according to IEC 61850-7-2.	sbo-with-normal-security	SBO control with normal security according to IEC 61850-7-2.	direct-with-enhanced-security	Direct control with enhanced security according to IEC 61850-7-2.	sbo-with-enhanced-security	SBO control with enhanced security according to IEC 61850-7-2.
Value	Explanation												
status-only	The object is not controllable, only the services that apply to a status object are supported. The attribute ctIVal does not exist.												
direct-with-normal-security	Direct control with normal security according to IEC 61850-7-2.												
sbo-with-normal-security	SBO control with normal security according to IEC 61850-7-2.												
direct-with-enhanced-security	Direct control with enhanced security according to IEC 61850-7-2.												
sbo-with-enhanced-security	SBO control with enhanced security according to IEC 61850-7-2.												
ctINum	<p>If the change of the status was caused by a control, the content shall show the control sequence number of the control service. All service primitives belonging to one control sequence shall be identified by the same control sequence number. The use of ctINum is an issue of the client. The only thing that the server shall do with ctINum is to include it in the responses to the control model and in the reports about a status change that is caused by a command.</p> <p><u>As a service parameter, CtINum is applicable for the following services:</u></p> <p><u>SeIVal (Request, Response+, Response-)</u> <u>Operate (Request, Response+, Response-)</u> <u>TimOper (Request, Response+, Response-)</u></p>												
ctIVal	<p><u>Service parameter that determines the control activity.</u></p> <p>For the CDC INC, the integer value 0 shall be transmitted to reset the value.</p> <p>For the CDC BSC, if the data attribute persistent is FALSE, higher and lower refer to one step in the data attribute posVal of the data attribute valWTr.</p> <p>For the CDC ISC, the INTEGER value refers always to a dedicated position in the data attribute posVal of the data attribute valWTr which has to be reached directly.</p> <p><u>The service parameter is applicable for the following services:</u></p> <p><u>SeIVal (Request, Response+, Response-)</u> <u>Operate (Request, Response+, Response-)</u> <u>TimOper (Request, Response+, Response-)</u></p>												
cVal	<p>Deadbanded complex value. Based on a deadband calculation from instCVal. The deadband calculation is done both on instCVal.mag <u>based on the configuration parameter db</u> as well as on instCVal.ang <u>based on the configuration parameter dbAng</u> independently. For details on deadband calculation, see mag.</p>												
d	<p>Textual description of the data. In case of the common data class LPL, the description refers to the logical node.</p>												
dataNs	<p>Data name space. For details see IEC 61850-7-1.</p>												
db	<p>Deadband. Shall represent a configuration parameter used to calculate all deadbanded attributes (for example mag attribute in the CDC MV). The value shall represent the percentage of difference between max and min in units of 0,001 %.</p> <p>If an integral calculation is used to determine the deadbanded value, the value shall be represented as 0,001 % s.</p>												
dbAng	<p><u>Deadband for angles. Shall represent a configuration parameter used to calculate deadbanded attributes for the angle in the case the data attribute is of the common data attribute type Vector (for example cVal attribute of the CDC CMV). The value shall represent the percentage of difference between max and min in units of 0.001 %.</u></p> <p><u>If an integral calculation is used to determine the deadbanded value, the value shall be represented as 0.001 % s.</u></p>												
dirGeneral	<p>General direction of the fault. If the faults of individual phases have different directions, this attribute shall be set to both.</p>												

Comment [CB80]: TISSUE #173

Comment [CB81]: TISSUE #173


Deleted: D

Comment [CB82]: TISSUE #65

Comment [CB83]: TISSUE #65

Data attribute name	Semantics
dirNeut	Direction of the fault for neut.
dirPhsA	Direction of the fault for phase A.
dirPhsB	Direction of the fault for phase B.
dirPhsC	Direction of the fault for phase C.
dU	Textual description of the data using unicode characters. For further details, see d.
<u>ePSName</u>	<u>Name of electric power system the device is connected to</u>
evalTm	Time window applied to interharmonic calculations. The value shall be represented in ms. For further details, see har.
frEna	BOOLEAN value, which controls the freeze, process. If TRUE, freezing shall occur as specified in strTm, frPd and frRs. If FALSE, no freezing shall occur.
frequency	Nominal frequency of the power system or some other fundamental frequency in Hz.
frPd	Time interval in ms between freeze operations. If frPd is 0, only a single freeze is performed at the time indicated in strTm.
frRs	Indicates that counter is to be automatically reset to zero after each freezing process.
frTm	Time of the last counter freeze.
frVal	Frozen binary counter status represented as an integer value.
general	Logical "or" of the phase values, for example trip or start. The attribute shall also be set if not all phases have a fault condition.
har	<p>This array shall contain the harmonic and subharmonic or the interharmonic values.</p> <p>harmonic and subharmonic values (evalTm equal to the period of the power frequency)</p> <p>The first array element shall contain the dc components, the further array elements shall contain the values for the harmonics 1 .. numHar. If numCycl is larger than one, then the array shall contain both harmonics and subharmonics and their multiples. In that case, sequence entries with the number $n \times 2^{numCycl-1}$ are harmonics; all other ones are subharmonics or multiple of subharmonics.</p> <p>interharmonic values (evalTm not equal to the period of the power frequency)</p> <p>The first array element shall contain the dc components, the further array elements shall contain the values for the harmonics 1 .. numHar.</p>
<u>hstRangeC</u>	<u>This array shall contain the values for the configuration of the ranges for the histogram. For details see hst.</u>
<u>hstRangeUnit</u>	<u>This attribute shall represent the unit of the values that are evaluated with a histogram. For details see hst.</u>


Formatted: Not Highlight

Data attribute name	Semantics
<u>hstVal</u>	<p data-bbox="336 264 1201 309"><u>This array shall contain the values for the histogram entries. Details of the histogram representation are shown in the figure below.</u></p>  <p data-bbox="336 913 1201 1003"><u>A histogram evaluates a series of values and counts the appearance of a value in a certain range. The value range is configured with the configuration attribute hstRangeC. The attribute hstCnt[1] shall be the count of the appearance of the evaluated values in the range between hstRangeC[1] and hstRangeC[2].</u></p>
hvRef	Specifies the reference type (i.e. ratio of harmonic to fundamental, to RMS or to absolute), which the data attribute mag of the data attribute type Vector contain.
hwRev	HW-revision.
<u>IntAddr</u>	<u>this value represents a manufacturer specific internal address</u>
instCVal	Instant value of a vector type value.
instMag	Magnitude of a the instantaneous value of a measured value.
<u>Latitude</u>	<u>GPS position of device – latitude</u>
IdNs	Logical device name space. For details see IEC 61850-7-1.
InNs	Logical node name space. For details see IEC 61850-7-1.
location	Location, where the equipment is installed.
<u>Longitude</u>	<u>GPS position of device – longitude</u>

Comment [CB84]: TISSUE #216, 217

Formatted: Not Highlight

Formatted: Not Highlight

Data attribute name	Semantics
mag	<p>Deadbanded value. Shall be based on a dead band calculation from the instantaneous value modelled as instMag as illustrated below. The value of mag shall be updated to the current value of instMag when the value has changed according the configuration parameter db.</p>  <p>NOTE 3 The figure above is an example. There may be other algorithms providing a comparable result; for example as an alternate solution, the dead band calculation may use the integral of the change of instMag. The algorithm used is a local issue.</p> <p>NOTE 4 This value mag is typically used to create reports for analogue values. Such a report sent "by exception" is not comparable to the transfer of sampled measured values as supported by the CDC SAV.</p> <p><u>NOTE</u> – the data attribute mag explained here is not the same like the data attribute component mag of the common data attribute type vector. Therefore in particular the value instCVal.mag is NOT a deadbanded value.</p>
magSVC	Scaled value configuration for magnitude. Shall be used to configure the scaled value representation of the magnitude in a vector.
max	Maximum process measurement for which values of <i>i</i> or <i>f</i> are considered within process limits. If the value is higher, q shall be set accordingly (validity = questionable, detailQual = outOfRange).
maxVal	Defines together with minVal the setting range for ctiVal (CDC INC, BSC, ISC), setVal (CDC ING) or setMag (CDC APC, ASG).
min	Minimum process measurement for which values of <i>i</i> or <i>f</i> are considered within process limits. If the value is lower, q shall be set accordingly (validity = questionable, detailQual = outOfRange).
minVal	Defines together with maxVal the setting range for ctiVal (CDC INC, BSC, ISC), setVal (CDC ING) or setMag (CDC APC, ASG).
model	Vendor specific product name.
mxVal	Measured analogue process value. The back indication from a controllable analogue process value.
net	Net current. Net current is the algebraic sum of the instantaneous values of currents flowing through all live conductors (sum over phase currents) and neutral of a circuit at a point of the electrical installation. <u>For further details see phsA (WYE)</u>
netHar	This array shall contain the harmonic and subharmonics or interharmonic values related to net current. For further details see Har.
neut (WYE)	<u>Value of the measured phase neutral. If a direct measurement of this value is not available, it is acceptable to substitute an estimate computed by creating the algebraic sum of the instantaneous values of currents flowing through all live conductors. In that case, 'neut' is identical to 'res'.</u> For further details see phsA (WYE).
neut (ACT, ACD)	Start event with earth current.
neutHar	This array shall contain the harmonic and subharmonics or interharmonic values related to neutral. For further details see Har.
numCyc	Number of cycles of power frequency, which are used for harmonic, subharmonic and interharmonic calculation. For further details see har.
numHar	Number of harmonic and subharmonics or interharmonic values that <u>can be accessed</u> . The range of the numHar value shall be 1 or greater. <u>The array element "1" shall represent the first harmonic value.</u> The value 0 shall refer to the dc component. The maximal value for numHar may be calculated as follows: $numHar = \frac{1}{2} \times smpRate \times frequency \times evalTm \times 2^{numCycl-1} + 1$

Comment [CB85]: TISSUE #63

Deleted: 7

Deleted: 8

Comment [CB86]: TISSUE #63

Comment [CB87]: TISSUE #28

Comment [CB88]: TISSUE #55

Comment [CB89]: TISSUE #55

Deleted: Value of phase neutral.

Deleted: are to be returned as the value attribute

Deleted: than 0

Data attribute name	Semantics
numPts	Number of points used to define a curve <u>or a histogram</u> .
operTm	If the service TimeActivatedOperate is performed, then this attribute shall specify the absolute time when the command shall be executed. <u>The service parameter is applicable for the following services:</u> <u>SetVal (Request, Response+, Response-)</u> <u>Operate (Request, Response+, Response-)</u> <u>TimOper (Request, Response+, Response-)</u>
operTmPhsA	Operation Time <u>for Phase A</u> . Is used for point on wave switching.
operTmPhsB	Operation Time <u>for Phase B</u> . Is used for point on wave switching.
operTmPhsC	Operation Time <u>for Phase C</u> . Is used for point on wave switching.
origin	Contains information related to the originator of the last change of the controllable value of the data. <u>As a service parameter, origin is applicable for the following services:</u> <u>SetVal (Request, Response+, Response-)</u> <u>Operate (Request, Response+, Response-)</u> <u>TimOper (Request, Response+, Response-)</u>
owner	<u>Owner of the device</u>
paramRev	<u>Uniquely identifies the parameter revision of a logical device or logical node instance. ParamRev has to be changed at least on any change of a parameter within this logical device or logical node. How this is detected and performed is left to the user. For further details see as well Annex C.</u>
persistent	Configures the control output. If set to FALSE, the operate service results in the change of exactly one step higher or lower as defined with cliVal. If set to TRUE, the operate service initiates the persistent activation of the output. The output shall be deactivated by an operate service with the value stop or by a local timeout. A client may repeat sending the operate service in order to retrigger the output.
phsA (WYE)	Value of phase A. In the WYE class, values for phsA, phsB, phsC neut, net and res have been simultaneously acquired or determined. It shall be assumed that any jitter between the acquisition times dedicated for phsA, phsB, phsC neut, net and res is neglectable. The jitter for simultaneity shall be as indicated in the time quality field.
phsA (ACT, ACD)	Trip or start event of phase A.
phsAB	Value of phase A to phase B measurement. In the DEL class, values for phsAB, phsBC and phsCA have been simultaneously acquired or determined. It shall be assumed that any jitter between the acquisition times dedicated for phsAB, phsBC and phsCA is neglectable. The jitter for simultaneity shall be as indicated in the time quality field.
phsABHar	This array shall contain the harmonic and subharmonics or interharmonic values related to phase A to phase B. For further details see Har.
phsAHar	This array shall contain the harmonic and subharmonics or interharmonic values related to phase A. For further details see Har.
phsB (WYE)	Value of phase B. For further details see phsA (WYE).
phsB (ACT, ACD)	Trip or start event of phase B.
phsBC	Value of phase B to phase C measurement. For further details see phsAB.
phsBCHar	This array shall contain the harmonic and subharmonics or interharmonic values related to phase B to phase C. For further details see Har.
phsBHar	This array shall contain the harmonic and subharmonics or interharmonic values related to phase B. For further details see Har.
phsC (WYE)	Value of phase C. For further details see phsA (WYE).
phsC (ACT, ACD)	Trip or start event of phase C.
phsCA	Value of phase C to phase A measurement. For further details see phsAB.

Comment [CB90]: TISSUE #173

Deleted: (control classes)

Deleted: (ACT)

Comment [CB91]: TISSUE #219

Comment [CB92]: TISSUE #173

Formatted: Not Highlight

Comment [CB93]: TISSUE #424

Data attribute name	Semantics																																								
phsCAHar	This array shall contain the harmonic and subharmonics or interharmonic values related to phase C to phase A. For further details see Har.																																								
phsCHar	This array shall contain the harmonic and subharmonics or interharmonic values related to phase C. For further details see Har.																																								
phsRef	Indicates which phase has been used as reference for the transformation of phase values to sequence values.																																								
pointZ	position of the curve on z-axis.																																								
primeOper	Primary operator of device																																								
pulseConfig	Used to configure the output pulse generated with the command if applicable.																																								
pulsQty	Magnitude of the counted value per count. actVal/frVal and pulsQty are used to calculate the value: $value = actVal \times pulsQty$ $value = frVal \times pulsQty$																																								
q	Quality of the attribute(s) representing the value of the data. For the different CDCs q applies to the following data attributes: <table border="1" data-bbox="335 689 1037 1160"> <thead> <tr> <th>CDC</th> <th>data attribute q applies to</th> </tr> </thead> <tbody> <tr><td>SPS</td><td>stVal</td></tr> <tr><td>DPS</td><td>stVal</td></tr> <tr><td>INS</td><td>stVal</td></tr> <tr><td>ACT</td><td>general, phsA, phsB, phsC, neut</td></tr> <tr><td>ACD</td><td>general, dirGeneral, phsA, dirPhsA, phsB, dirPhsB, phsC, dirPhsC, neut, dirNeut</td></tr> <tr><td>BCR</td><td>actVal, frVal</td></tr> <tr><td>HST</td><td>hstCnt</td></tr> <tr><td>MV</td><td>instMag, Mag, range</td></tr> <tr><td>CMV</td><td>instCMag, cMag, range</td></tr> <tr><td>SAV</td><td>instMag</td></tr> <tr><td>HMV</td><td>Har</td></tr> <tr><td>HWYE</td><td>phsAHar, phsBHar, phsCHar, neutHar, netHar, resHar</td></tr> <tr><td>HDEL</td><td>phsABHar, phsBCHar, phsCAHar</td></tr> <tr><td>SPC</td><td>stVal</td></tr> <tr><td>DPC</td><td>stVal</td></tr> <tr><td>INC</td><td>stVal</td></tr> <tr><td>BSC</td><td>valWTr</td></tr> <tr><td>ISC</td><td>valWTr</td></tr> <tr><td>APC</td><td>setMag</td></tr> </tbody> </table>	CDC	data attribute q applies to	SPS	stVal	DPS	stVal	INS	stVal	ACT	general, phsA, phsB, phsC, neut	ACD	general, dirGeneral, phsA, dirPhsA, phsB, dirPhsB, phsC, dirPhsC, neut, dirNeut	BCR	actVal, frVal	HST	hstCnt	MV	instMag, Mag, range	CMV	instCMag, cMag, range	SAV	instMag	HMV	Har	HWYE	phsAHar, phsBHar, phsCHar, neutHar, netHar, resHar	HDEL	phsABHar, phsBCHar, phsCAHar	SPC	stVal	DPC	stVal	INC	stVal	BSC	valWTr	ISC	valWTr	APC	setMag
CDC	data attribute q applies to																																								
SPS	stVal																																								
DPS	stVal																																								
INS	stVal																																								
ACT	general, phsA, phsB, phsC, neut																																								
ACD	general, dirGeneral, phsA, dirPhsA, phsB, dirPhsB, phsC, dirPhsC, neut, dirNeut																																								
BCR	actVal, frVal																																								
HST	hstCnt																																								
MV	instMag, Mag, range																																								
CMV	instCMag, cMag, range																																								
SAV	instMag																																								
HMV	Har																																								
HWYE	phsAHar, phsBHar, phsCHar, neutHar, netHar, resHar																																								
HDEL	phsABHar, phsBCHar, phsCAHar																																								
SPC	stVal																																								
DPC	stVal																																								
INC	stVal																																								
BSC	valWTr																																								
ISC	valWTr																																								
APC	setMag																																								
range	Range in which the current value of instMag or instCVal.mag is. It may be used to issue an event if the current value changes and transitions to another range. Range shall be used in the context with configuration attributes like hhLim, hLim, lLim, lLim, min and max as shown below. <table border="1" data-bbox="335 1288 1197 1601"> <thead> <tr> <th></th> <th>range</th> <th>validity</th> <th>detail-qual</th> </tr> </thead> <tbody> <tr> <td></td> <td>high-high</td> <td>questionable</td> <td>outOfRange</td> </tr> <tr> <td>max</td> <td>high-high</td> <td>good</td> <td></td> </tr> <tr> <td>hhLim</td> <td>high</td> <td>good</td> <td></td> </tr> <tr> <td>hLim</td> <td>normal</td> <td>good</td> <td></td> </tr> <tr> <td>lLim</td> <td>low</td> <td>good</td> <td></td> </tr> <tr> <td>llLim</td> <td>low-low</td> <td>good</td> <td></td> </tr> <tr> <td>min</td> <td>low-low</td> <td>questionable</td> <td>outOfRange</td> </tr> </tbody> </table> <p>NOTE 5. The use of algorithms to filter events based on transition from one range to another is a local issue.</p> <p>NOTE 6. This value with the trigger option "data-change" as described in 61850-7-2 may be used to report an event to the client.</p>		range	validity	detail-qual		high-high	questionable	outOfRange	max	high-high	good		hhLim	high	good		hLim	normal	good		lLim	low	good		llLim	low-low	good		min	low-low	questionable	outOfRange								
	range	validity	detail-qual																																						
	high-high	questionable	outOfRange																																						
max	high-high	good																																							
hhLim	high	good																																							
hLim	normal	good																																							
lLim	low	good																																							
llLim	low-low	good																																							
min	low-low	questionable	outOfRange																																						
rangeAng	Range in which the current value of instCVal.ang is. For further details see range																																								

Comment [CB94]: New CDC CSG
Formatted: Not Highlight

Deleted: 9

Deleted: 10

Comment [CB95]: TISSUE #482

Data attribute name	Semantics												
<u>rangeAngC</u>	<u>Configuration parameters as used in the context with the rangeAng attribute.</u>												
rangeC	Configuration parameters as used in the context with the range attribute.												
res	Residual current. Residual current is the algebraic sum of the instantaneous values of currents flowing through all live conductors (i.e. sum over phase currents) of a circuit at a point of the electrical installation. <u>For further details see phsA (WYE)</u>												
resHar	This array shall contain the harmonic and subharmonics or interharmonic values related to residual current. For further details, see Har.												
rmsCyc	Number of cycles of power frequency, which are used for the calculation of rms values.												
<u>role</u>	<u>Role of the device</u>												
sboClass	Specifies the SBO-class according to the control model of IEC 61850-7-2 that corresponds to the behaviour of the data. The following values are defined: <table border="1" data-bbox="336 602 1035 734"> <thead> <tr> <th>value</th> <th></th> </tr> </thead> <tbody> <tr> <td>operate-once</td> <td>Following an operate request, the control object shall return in the unselected state.</td> </tr> <tr> <td>operate-many</td> <td>Following an operate request, the control object shall remain in the ready state, as long as sboTimeout did not expire.</td> </tr> </tbody> </table>	value		operate-once	Following an operate request, the control object shall return in the unselected state.	operate-many	Following an operate request, the control object shall remain in the ready state, as long as sboTimeout did not expire.						
value													
operate-once	Following an operate request, the control object shall return in the unselected state.												
operate-many	Following an operate request, the control object shall remain in the ready state, as long as sboTimeout did not expire.												
sboTimeout	Specifies the timeout according to the control model of IEC 61850-7-2 that corresponds to the behaviour of the data. The value shall be in ms.												
<u>secondOper</u>	<u>Secondary operator of device</u>												
seqT	This attribute shall specify the type of the sequence. The following values are used: <table border="1" data-bbox="336 898 825 969"> <thead> <tr> <th>value</th> <th>c1</th> <th>c2</th> <th>c3</th> </tr> </thead> <tbody> <tr> <td>pos-neg-zero</td> <td>pos</td> <td>neg</td> <td>zero</td> </tr> <tr> <td>dir-quad-zero</td> <td>dir</td> <td>quad</td> <td>zero</td> </tr> </tbody> </table>	value	c1	c2	c3	pos-neg-zero	pos	neg	zero	dir-quad-zero	dir	quad	zero
value	c1	c2	c3										
pos-neg-zero	pos	neg	zero										
dir-quad-zero	dir	quad	zero										
serNum	Serial number.												

Comment [CB96]: TISSUE #55

Formatted: Not Highlight

Formatted: Not Highlight

Data attribute name	Semantics																																														
setCharact	<p>This attribute shall describe the curve characteristic. The values are defined below. Each curve is of the form $x = f(y)$. There are three options to describe $f(y)$:</p> <ol style="list-style-type: none"> characteristic = 1 ... 16: As a formula based on up to 6 parameters A, B, C, D, E and F. The formula is standardised by ANSI or IEC. ANSI and IEC also specify the values for A, B, C, D, E and F in that case, the corresponding attributes (setParA, ..., setParF) are read-only. characteristic = 17 ... 32: As a definable formula based on up to 6 parameters A, B, C, D, E and F. In that case it may be possible, that the parameters may be modified. The specification of the formula is a local issue. The actual shape of the curve may be read out using a dedicated data of the CDC CSD. characteristic = 33 ... 48: As a definable curve specified as an array of (x,y) pairs. The specification of the array is a local issue. The actual shape of the curve may be read out using a dedicated data of the CDC CSD. <table border="1" data-bbox="336 584 1051 1099"> <thead> <tr> <th>value</th> <th>curve characteristic</th> </tr> </thead> <tbody> <tr><td>1</td><td>ANSI Extremely Inverse</td></tr> <tr><td>2</td><td>ANSI Very Inverse</td></tr> <tr><td>3</td><td>ANSI Normal Inverse</td></tr> <tr><td>4</td><td>ANSI Moderately Inverse</td></tr> <tr><td>5</td><td>ANSI Definite Time (Definite Time Over Current = default)</td></tr> <tr><td>6</td><td>Long-Time Extremely Inverse</td></tr> <tr><td>7</td><td>Long-Time Very Inverse</td></tr> <tr><td>8</td><td>Long-Time Inverse</td></tr> <tr><td>9</td><td>IEC Normal Inverse</td></tr> <tr><td>10</td><td>IEC Very Inverse</td></tr> <tr><td>11</td><td>IEC Inverse</td></tr> <tr><td>12</td><td>IEC Extremely Inverse</td></tr> <tr><td>13</td><td>IEC Short-Time Inverse</td></tr> <tr><td>14</td><td>IEC Long-Time Inverse</td></tr> <tr><td>15</td><td>IEC Definite Time</td></tr> <tr><td>16</td><td>Reserved</td></tr> <tr><td>17</td><td>Definable curve 1 based on formula $[x=f(y,A,B,C,D, E, F)]$</td></tr> <tr><td>...</td><td></td></tr> <tr><td>32</td><td>Definable curve 16 based on formula $[x=f(y,A,B,C,D, E, F)]$</td></tr> <tr><td>33</td><td>Vendor specific curve 1 defined by n pairs (x,y)</td></tr> <tr><td>...</td><td></td></tr> <tr><td>48</td><td>Vendor specific curve 16 defined by n pairs (x,y)</td></tr> </tbody> </table>	value	curve characteristic	1	ANSI Extremely Inverse	2	ANSI Very Inverse	3	ANSI Normal Inverse	4	ANSI Moderately Inverse	5	ANSI Definite Time (Definite Time Over Current = default)	6	Long-Time Extremely Inverse	7	Long-Time Very Inverse	8	Long-Time Inverse	9	IEC Normal Inverse	10	IEC Very Inverse	11	IEC Inverse	12	IEC Extremely Inverse	13	IEC Short-Time Inverse	14	IEC Long-Time Inverse	15	IEC Definite Time	16	Reserved	17	Definable curve 1 based on formula $[x=f(y,A,B,C,D, E, F)]$...		32	Definable curve 16 based on formula $[x=f(y,A,B,C,D, E, F)]$	33	Vendor specific curve 1 defined by n pairs (x,y)	...		48	Vendor specific curve 16 defined by n pairs (x,y)
value	curve characteristic																																														
1	ANSI Extremely Inverse																																														
2	ANSI Very Inverse																																														
3	ANSI Normal Inverse																																														
4	ANSI Moderately Inverse																																														
5	ANSI Definite Time (Definite Time Over Current = default)																																														
6	Long-Time Extremely Inverse																																														
7	Long-Time Very Inverse																																														
8	Long-Time Inverse																																														
9	IEC Normal Inverse																																														
10	IEC Very Inverse																																														
11	IEC Inverse																																														
12	IEC Extremely Inverse																																														
13	IEC Short-Time Inverse																																														
14	IEC Long-Time Inverse																																														
15	IEC Definite Time																																														
16	Reserved																																														
17	Definable curve 1 based on formula $[x=f(y,A,B,C,D, E, F)]$																																														
...																																															
32	Definable curve 16 based on formula $[x=f(y,A,B,C,D, E, F)]$																																														
33	Vendor specific curve 1 defined by n pairs (x,y)																																														
...																																															
48	Vendor specific curve 16 defined by n pairs (x,y)																																														
setParA	Attribute used to set the parameter A of the setting curve (see detailed description under setCharact).																																														
setParB	Attribute used to set the parameter B of the setting curve (see detailed description under setCharact).																																														
setParC	Attribute used to set the parameter C of the setting curve (see detailed description under setCharact).																																														
setParD	Attribute used to set the parameter D of the setting curve (see detailed description under setCharact).																																														
setParE	Attribute used to set the parameter E of the setting curve (see detailed description under setCharact).																																														
setParF	Attribute used to set the parameter F of the setting curve (see detailed description under setCharact).																																														
setRef	The value of an object reference setting. The attribute may be used to reference a logical node instance.																																														
setMag	The value of an analogue setting or set point.																																														
setTm	The value of a time setting.																																														
setVal	The value of a status setting.																																														

Comment [CB97]: Historical and Statistical

Data attribute name	Semantics																						
sev	Severity of the last violation detected. The values are: <table border="1" data-bbox="336 300 1037 521"> <thead> <tr> <th>value</th> <th></th> </tr> </thead> <tbody> <tr> <td>unknown</td> <td>Severity cannot be determined.</td> </tr> <tr> <td>critical</td> <td>Severity is critical in terms of safe operation or data considered critical and privileged access was attempted.</td> </tr> <tr> <td>major</td> <td>Severity is major in terms of safe operation or data considered of major importance and privileged access was attempted.</td> </tr> <tr> <td>minor</td> <td>Severity is minor in the sense that access control was denied to data considered privileged.</td> </tr> <tr> <td>warning</td> <td>Is less severe than minor.</td> </tr> </tbody> </table>	value		unknown	Severity cannot be determined.	critical	Severity is critical in terms of safe operation or data considered critical and privileged access was attempted.	major	Severity is major in terms of safe operation or data considered of major importance and privileged access was attempted.	minor	Severity is minor in the sense that access control was denied to data considered privileged.	warning	Is less severe than minor.										
value																							
unknown	Severity cannot be determined.																						
critical	Severity is critical in terms of safe operation or data considered critical and privileged access was attempted.																						
major	Severity is major in terms of safe operation or data considered of major importance and privileged access was attempted.																						
minor	Severity is minor in the sense that access control was denied to data considered privileged.																						
warning	Is less severe than minor.																						
smpRate (H MV, HWYE, HDEL)	Determines according to the sampling theorem the highest possible harmonic or interharmonic detectable. The minimum is $2 \times$ frequency. The value shall represent the number of samples per nominal period. In the case of a d.c. system, the value shall represent the number of samples per s.																						
smpRate (M V, CMV, WYE, DEL)	Sampling rate that has been used to determine the analogue values. The value shall represent the number of samples per nominal period. In the case of a d.c. system, the value shall represent the number of samples per s.																						
stepSize	Defines the step between individual values that ctiVal (CDC INC, BSC, ISC), setVal (CDC ING) or setMag (CDC APC, ASG) will accept.																						
strTm	Starting time of the freeze process. If the current time is later than the start time, the first freeze shall occur at the next freeze interval (frPd) expiration, computed from the start time setting.																						
stSeld	The controllable data is in the status "selected".																						
stVal	Status value of the data.																						
subCVal	Value used to substitute the data attribute instCVal.																						
subEna	Used to enable substitution. If this attribute is set to true, the attribute(s) representing the value of the data instance shall always be set to the same value as the attribute(s) used to store the substitution value of the data. If this attribute is set to false, the attribute(s) representing the value of the data instance shall be based on the process value. For the different CDCs subEna applies to the following data attributes: <table border="1" data-bbox="336 1081 1037 1328"> <thead> <tr> <th>CDC</th> <th>data attribute subEna applies to</th> </tr> </thead> <tbody> <tr> <td>SPS</td> <td>stVal and subVal, q and subQ</td> </tr> <tr> <td>DPS</td> <td>stVal and subVal, q and subQ</td> </tr> <tr> <td>INS</td> <td>stVal and subVal, q and subQ</td> </tr> <tr> <td>MV</td> <td>instMag and subMag, q and subQ</td> </tr> <tr> <td>CMV</td> <td>instCVal and subCVal, q and subQ</td> </tr> <tr> <td>SPC</td> <td>stVal and subVal, q and subQ</td> </tr> <tr> <td>DPC</td> <td>stVal and subVal, q and subQ</td> </tr> <tr> <td>INC</td> <td>stVal and subVal, q and subQ</td> </tr> <tr> <td>BSC</td> <td>valWTr and subVal, q and subQ</td> </tr> <tr> <td>ISC</td> <td>valWTr and subVal, q and subQ</td> </tr> </tbody> </table> <p>It is the responsibility of the client application, in particular in the case of multiple attributes to be substituted, to set all relevant substitution values before enabling substitution. To prevent wrong operation in a specific mapping to one Get-Service request, the substitution is recommended to be mapped to two setDataValue services: the first one to set the substitution values and the second to set subEna to true.</p>	CDC	data attribute subEna applies to	SPS	stVal and subVal, q and subQ	DPS	stVal and subVal, q and subQ	INS	stVal and subVal, q and subQ	MV	instMag and subMag, q and subQ	CMV	instCVal and subCVal, q and subQ	SPC	stVal and subVal, q and subQ	DPC	stVal and subVal, q and subQ	INC	stVal and subVal, q and subQ	BSC	valWTr and subVal, q and subQ	ISC	valWTr and subVal, q and subQ
CDC	data attribute subEna applies to																						
SPS	stVal and subVal, q and subQ																						
DPS	stVal and subVal, q and subQ																						
INS	stVal and subVal, q and subQ																						
MV	instMag and subMag, q and subQ																						
CMV	instCVal and subCVal, q and subQ																						
SPC	stVal and subVal, q and subQ																						
DPC	stVal and subVal, q and subQ																						
INC	stVal and subVal, q and subQ																						
BSC	valWTr and subVal, q and subQ																						
ISC	valWTr and subVal, q and subQ																						
subID	Shows the address of the device that made the substitution. The value of null shall be used if subEna is false or if the device is not known.																						
subMag	Value used to substitute the data attribute instMag.																						
subQ	Value used to substitute the data attribute q.																						

Formatted: Italian (Italy)

Data attribute name	Semantics																																										
subVal	Value used to substitute the attribute representing the value of the data instance. For the different CDCs subVal is used to substitute the following data attributes: <table border="1" data-bbox="336 320 1035 521"> <thead> <tr> <th>CDC</th> <th>data attribute subVal is used to substitute</th> </tr> </thead> <tbody> <tr><td>SPS</td><td>stVal</td></tr> <tr><td>DPS</td><td>stVal</td></tr> <tr><td>INS</td><td>stVal</td></tr> <tr><td>SPC</td><td>stVal</td></tr> <tr><td>DPC</td><td>stVal</td></tr> <tr><td>INC</td><td>stVal</td></tr> <tr><td>BSC</td><td>valWTr</td></tr> <tr><td>ISC</td><td>valWTr</td></tr> </tbody> </table>	CDC	data attribute subVal is used to substitute	SPS	stVal	DPS	stVal	INS	stVal	SPC	stVal	DPC	stVal	INC	stVal	BSC	valWTr	ISC	valWTr																								
CDC	data attribute subVal is used to substitute																																										
SPS	stVal																																										
DPS	stVal																																										
INS	stVal																																										
SPC	stVal																																										
DPC	stVal																																										
INC	stVal																																										
BSC	valWTr																																										
ISC	valWTr																																										
sVC	Scaled value configuration. Shall be used to configure the scaled value representation of instMag, mag, subMag or setMag.																																										
swRev	SW-revision.																																										
t	<p>T shall be the time, when the client sends the service request. The parameter is applicable for the following services:</p> <p>SetVal (Request, Response+, Response-) Cancel (Request, Response+, Response-) Operate (Request, Response+, Response-) CmdTerm (Response+, Response-) TimOper (Request, Response+, Response-)</p>																																										
t	Timestamp of the last change in one of the attribute(s) representing the value of the data or in the q attribute. For the different CDCs t applies to the following data attributes: <table border="1" data-bbox="336 902 1035 1395"> <thead> <tr> <th>CDC</th> <th>data attribute t applies to</th> </tr> </thead> <tbody> <tr><td>SPS</td><td>stVal</td></tr> <tr><td>DPS</td><td>stVal</td></tr> <tr><td>INS</td><td>stVal</td></tr> <tr><td>ACT</td><td>general, phsA, phsB, phsC, neut</td></tr> <tr><td>ACD</td><td>general, dirGeneral, phsA, dirPhsA, phsB, dirPhsB, phsC, dirPhsC, neut, dirNeut</td></tr> <tr><td>SEC</td><td>cnt</td></tr> <tr><td>BCR</td><td>actVal</td></tr> <tr><td>HST</td><td>hstCnt</td></tr> <tr><td>MV</td><td>mag, range</td></tr> <tr><td>CMV</td><td>cVal, range</td></tr> <tr><td>SAV</td><td>instMag</td></tr> <tr><td>HMV</td><td>Har</td></tr> <tr><td>HWYE</td><td>phsAHar, phsBHar, phsCHar, neutHar, netHar, resHar</td></tr> <tr><td>HDEL</td><td>phsABHar, phsBCHar, phsCAHar</td></tr> <tr><td>SPC</td><td>stVal</td></tr> <tr><td>DPC</td><td>stVal</td></tr> <tr><td>INC</td><td>stVal</td></tr> <tr><td>BSC</td><td>valWTr</td></tr> <tr><td>ISC</td><td>valWTr</td></tr> <tr><td>APC</td><td>setMag</td></tr> </tbody> </table>	CDC	data attribute t applies to	SPS	stVal	DPS	stVal	INS	stVal	ACT	general, phsA, phsB, phsC, neut	ACD	general, dirGeneral, phsA, dirPhsA, phsB, dirPhsB, phsC, dirPhsC, neut, dirNeut	SEC	cnt	BCR	actVal	HST	hstCnt	MV	mag, range	CMV	cVal, range	SAV	instMag	HMV	Har	HWYE	phsAHar, phsBHar, phsCHar, neutHar, netHar, resHar	HDEL	phsABHar, phsBCHar, phsCAHar	SPC	stVal	DPC	stVal	INC	stVal	BSC	valWTr	ISC	valWTr	APC	setMag
CDC	data attribute t applies to																																										
SPS	stVal																																										
DPS	stVal																																										
INS	stVal																																										
ACT	general, phsA, phsB, phsC, neut																																										
ACD	general, dirGeneral, phsA, dirPhsA, phsB, dirPhsB, phsC, dirPhsC, neut, dirNeut																																										
SEC	cnt																																										
BCR	actVal																																										
HST	hstCnt																																										
MV	mag, range																																										
CMV	cVal, range																																										
SAV	instMag																																										
HMV	Har																																										
HWYE	phsAHar, phsBHar, phsCHar, neutHar, netHar, resHar																																										
HDEL	phsABHar, phsBCHar, phsCAHar																																										
SPC	stVal																																										
DPC	stVal																																										
INC	stVal																																										
BSC	valWTr																																										
ISC	valWTr																																										
APC	setMag																																										
Test	<p>The parameter shall define, whether the information exchange is for test or for normal operation. The parameter is applicable for the following services:</p> <p>SetVal (Request, Response+, Response-) Cancel (Request, Response+, Response-) Operate (Request, Response+, Response-) CmdTerm (Response+, Response-) TimOper (Request, Response+, Response-)</p>																																										
jImOffset	Offset of local time from UTC in minutes																																										
jImUseDT	Flag indicating if this location is using daylight saving time																																										
jImDT	Flag indicating if for this location daylight saving time is in effect now																																										

Comment [CB99]: TISSUE #30

Comment [CB98]: TISSUE #173

Comment [CB100]: TISSUE #173

Comment [CB101]: WG10 Meeting Seoul

Formatted: Not Highlight

Formatted: Not Highlight

Formatted: Not Highlight

Formatted: Not Highlight

Formatted: Not Highlight

Data attribute name	Semantics																				
units	<p>Units of the attribute(s) representing the value of the data. For the different CDCs units applies to the following data attributes:</p> <table border="1" data-bbox="336 320 1038 566"> <thead> <tr> <th>CDC</th> <th>data attribute units applies to</th> </tr> </thead> <tbody> <tr> <td>BCR</td> <td>actVal, frVal</td> </tr> <tr> <td>MV</td> <td>instMag, mag</td> </tr> <tr> <td>CMV</td> <td>instCVal.Mag, cVal.Mag</td> </tr> <tr> <td>SAV</td> <td>instMag</td> </tr> <tr> <td>HMV</td> <td>har.Mag</td> </tr> <tr> <td>HWYE</td> <td>phsAHar.Mag, phsBHar.Mag, phsCHar.Mag, neutHar.Mag, netHar.Mag, resHar.Mmag</td> </tr> <tr> <td>HDEL</td> <td>phsAB.Mag, phsBC.Mag, phsCA.Mag</td> </tr> <tr> <td>APC</td> <td>setMag</td> </tr> <tr> <td>ASG</td> <td>setMag</td> </tr> </tbody> </table>	CDC	data attribute units applies to	BCR	actVal, frVal	MV	instMag, mag	CMV	instCVal.Mag, cVal.Mag	SAV	instMag	HMV	har.Mag	HWYE	phsAHar.Mag, phsBHar.Mag, phsCHar.Mag, neutHar.Mag, netHar.Mag, resHar.Mmag	HDEL	phsAB.Mag, phsBC.Mag, phsCA.Mag	APC	setMag	ASG	setMag
CDC	data attribute units applies to																				
BCR	actVal, frVal																				
MV	instMag, mag																				
CMV	instCVal.Mag, cVal.Mag																				
SAV	instMag																				
HMV	har.Mag																				
HWYE	phsAHar.Mag, phsBHar.Mag, phsCHar.Mag, neutHar.Mag, netHar.Mag, resHar.Mmag																				
HDEL	phsAB.Mag, phsBC.Mag, phsCA.Mag																				
APC	setMag																				
ASG	setMag																				
<u>valRev</u>	<p><u>Uniquely identifies the revision of the preconfiguration of configuration values (FC= CF, FC=ST) in a logical device or logical node instance through a SCL file. ValRev has to be changed at least on any change of preconfigured values within an SCL file for this logical device or logical node. How this is detected and performed is left to the user. For further details see as well Annex C.</u></p>																				
valWTr	Value with transient indication.																				
vendor	Name of the vendor.																				
xD	Description of the value of the x-axis of a curve.																				
xUnit	Unit of the x-axis of a curve.																				
yD	Description of the value of the y-axis of a curve.																				
yUnit	Unit of the y-axis of a curve.																				
<u>zD</u>	<u>Description of the value of the z-axis of a curve.</u>																				
zeroDb	<p>Configuration parameter used to calculate the range around zero, where the analogue value will be forced to zero. The value shall represent the percentage of difference between max and min in units of 0,001 %. For the different CDCs zeroDb applies to the following data attributes:</p> <table border="1" data-bbox="336 1055 1038 1122"> <thead> <tr> <th>CDC</th> <th>data attribute zeroDb applies to</th> </tr> </thead> <tbody> <tr> <td>MV</td> <td>mag</td> </tr> <tr> <td>CMV</td> <td>cVal.mag</td> </tr> </tbody> </table>	CDC	data attribute zeroDb applies to	MV	mag	CMV	cVal.mag														
CDC	data attribute zeroDb applies to																				
MV	mag																				
CMV	cVal.mag																				
<u>zUnit</u>	<u>Unit of the z-axis of a curve.</u>																				

Comment [CB102]: TISSU E #424

Annex A
(normative)

Value range for units and multiplier

The **units** shall be SI units, derived from ISO 1000, represented as an enumeration. The enumeration shall be as defined in Table A.1, Table A.2, Table A.3 and Table A.4. The multiplier shall be represented as an enumeration where the value of the enumeration equals the exponent of the multiplier value in base 10, as defined in Table A.5.

Formatted: French (France)

Table A.1 – SI units: base units

Value	Quantity	Unit name	Symbol
1	None	dimensionless	none
2	Length	meter	m
3	Mass	kilogram	kg
4	Time	second	s
5	Current	ampere	A
6	Temperature	Kelvin	K
7	Amount of substance	mole	mol
8	Luminous intensity	candela	cd

Table A.2 – SI units: derived units

Value	Quantity	Unit name	Symbol
9	Plane angle	degrees	deg
10	Plane angle	radian	rad
11	Solid angle	steradian	sr
21	Absorbed dose	Gray (J/Kg)	Gy
22	Activity	becquerel (l/s)	q
23	Relative temperature	degrees Celsius	°C
24	Dose equivalent	sievert (J/kg)	Sv
25	Electric capacitance	farad (C/V)	F
26	Electric charge	coulomb (AS)	C
27	Electric conductance	siemens (A/V)	S
28	Electric inductance	henry (Wb/A)	H
29	Electric potential	volt (W/A)	V
30	Electric resistance	ohm (V/A)	Ω
31	Energy	joule (N m)	J
32	Force	newton (kg m/s ²)	N
33	Frequency	hertz (1/s)	Hz
34	Illuminance	lux (lm/m ²)	lx
35	Luminous flux	lumen (cd sr)	Lm
36	Magnetic flux	weber (V s)	Wb
37	Magnetic flux density	tesla (Wb/m ²)	T
38	Power	watt (J/s)	W

Comment [CB103]: TISSU E #182

Value	Quantity	Unit name	Symbol
39	Pressure	pascal (N/m ²)	Pa

Table A.3 – SI units: extended units

Value	Quantity	Unit name	Symbol
41	Area	square meter (m ²)	m ²
42	Volume	cubic meter (m ³)	m ³
43	Velocity	meters per second (m/s)	ms ⁻¹
44	Acceleration	meters per second ² (m/s ²)	ms ⁻²
45	Volumetric flow rate	cubic meters per second (m ³ /s)	m ³ s ⁻¹
46	Fuel efficiency	meters/cubic meter (m/m ³)	m/m ³
47	Moment of mass	kilogram meter (kg m)	M
48	Density	kilogram/cubic meter (kg/m ³)	kg/m ³
49	Viscosity	meter square/second (m ² /s)	m ² /s
50	Thermal conductivity	watt/meter Kelvin (W/m K)	W/m K
51	Heat capacity	joule/Kelvin (J/K)	J/K
52	Concentration	parts per million	ppm
53	Rotational speed	rotations per second (1/s)	s ⁻¹
54	Angular velocity	radian per second (rad/s)	rads ⁻¹

Table A.4 – SI units: industry specific units

Value	Quantity	Unit name	Symbol
61	Apparent power	volt ampere (VA)	VA
62	Real power	watts (I ² R)	W
63	Reactive power	volt ampere reactive (VISinθ)	VA _r
64	Phase angle	degrees	θ
65	Power factor	(dimensionless)	Cosθ
66	Volt seconds	volt seconds (Ws/A)	Vs
67	Volts squared	volt square (W ² /A ²)	V ²
68	Amp seconds	amp second (As)	As
69	Amps squared	amp square (A ²)	A ²
70	Amps squared time	amp square second (A ² s)	A ² t
71	Apparent energy	volt ampere hours	VAh
72	Real energy	watt hours	Wh
73	Reactive energy	volt ampere reactive hours	VA _r h
74	Magnetic flux	volts per hertz	V/Hz
75	Rate of change of frequency	hertz per second	Hz/s
76	Number of characters	characters	char
77	Baud	characters per second	char/s
78	Turbine inertia	kg square meter	kgm²

Comment [CB104]: TISSU E #240

Comment [CB105]: TISSU E #327

Comment [CB106]: TISSU E #327

Comment [CB107]: TISSU E #519

Formatted: Superscript

Table A.5 – Multiplier

Value	Multiplier value	Name	Symbol
-24	10 ⁻²⁴	Yocto	y
-21	10 ⁻²¹	Zepto	z
-18	10 ⁻¹⁸	Atto	a
-15	10 ⁻¹⁵	Femto	f
-12	10 ⁻¹²	Pico	p
-9	10 ⁻⁹	Nano	n
-6	10 ⁻⁶	Micro	μ
-3	10 ⁻³	Milli	m
-2	10 ⁻²	Centi	c
-1	10 ⁻¹	Deci	d
0	1		
1	10 ¹	Deca	da
2	10 ²	Hecto	h
3	10 ³	Kilo	k
6	10 ⁶	Mega	M
9	10 ⁹	Giga	G
12	10 ¹²	Tera	T
15	10 ¹⁵	Peta	P
18	10 ¹⁸	Exa	E
21	10 ²¹	Zetta	Z
24	10 ²⁴	Yotta	Y

Comment [CB108]: TISSU E #414

Deleted: r

NOTE – A value that is representing a percentage can use the unit 1 (dimensionless) and a multiplier -2.

Comment [CB109]: TISSU E #247

Annex B (informative)

Functional constraints

The functional constraints are defined in IEC 61850-7-2. Those that are relevant for this part of IEC 61850 are repeated here for better reading of the standard.

Table B.1 – Functional constraints

Functional constraint (FC)					
	Semantic	Services allowed	Initial values/storage/ explanation	D ^a	CB ^b
ST	Status information	DataAttribute shall represent a status information whose value may be read, substituted, reported, and logged but shall not be written	Initial value of the DataAttribute shall be taken from the process	X	
MX	Measurands (analogue values)	DataAttribute shall represent a measurand information whose value may be read, substituted, reported, and logged but shall not be written	Initial value of the DataAttribute shall be taken from the process	X	
CO	Control	DataAttribute shall represent a control information whose value may be operated (control model) and read	N.a.	X	
SP	Setpoint	DataAttribute shall represent a set-point information whose value may be controlled (control model) and read. Values controlled shall become effective immediately	Initial value of the DataAttribute shall be as configured; value shall be non-volatile	X	X
SV	Substitution	DataAttribute shall represent a substitution information whose value may be written to substitute the value attribute and read	If the value of the DataAttribute is volatile then the initial value shall be FALSE, else the value should be as set or configured	X	
CF	Configuration	DataAttribute shall represent a configuration information whose value may be written and read. Values written may become effective immediately or deferred by reasons outside the scope of this standard	Initial value of the DataAttribute shall be as configured; value shall be non-volatile	X	
DC	Description	DataAttribute shall represent a description information whose value may be written and read	Initial value of the DataAttribute shall be as configured; value shall be non-volatile	X	
SG	Setting group	Logical devices that implement the SGCB class maintain multiple grouped values of all instances of DataAttributes with functional constraint SG. Each group contains one value for each DataAttribute with functional constraint SG which shall be the current active value (for details see 13). Values the of DataAttributes with FC=SG shall not be writeable	Initial value of the DataAttribute shall be as configured; value shall be non-volatile	X	
SE	Setting group editable	DataAttribute which can be edited by SGCB services	Value of the DataAttribute shall be as available after SelectEditSG service has been processed	X	
EX	Extended definition	DataAttribute shall represent an extension information providing a reference to a name space. Extensions are used in conjunction with extended definitions of LNs , DATA , and DataAttributes in 61850-7-3 and IEC 61850-7-4. Values the of DataAttributes with FC=EX shall not be writeable	Value of the DataAttribute shall be as configured; value shall be non-volatile	X	

Functional constraint (FC)					
	Semantic	Services allowed	Initial values/storage/ explanation	D ^a	CB ^b
BR	Buffered report ^c	Attribute shall represent a report control information of a BRCB whose value may be written and read	Initial value of the Attribute shall be as configured; value shall be non-volatile		X
RP	Unbuffered report ^c	Attribute shall represent a report control information of a URCB whose value may be written and read	Initial value of the Attribute shall be as configured; value shall be non-volatile		X
LG	Logging ^c	Attribute shall represent a log control information of a LCB whose value may be written and read	Initial value of the Attribute shall be as configured; value shall be non-volatile		X
GO	Goose control ^c	Attribute shall represent a goose control information of a GoCB whose value may be written and read	Initial value of the Attribute shall be as configured; value shall be non-volatile		X
GS	Gsse control ^c	Attribute shall represent a goose control information of a GsCB whose value may be written and read	Initial value of the Attribute shall be as configured; value shall be non-volatile		X
MS	Multicast sampled value control ^c	Attribute shall represent a sampled value control information of a MSVCB whose value may be written and read	Initial value of the Attribute shall be as configured; value shall be non-volatile		X
US	Unicast sampled value control ^c	Attribute shall represent a sampled value control information of an instance of a UNICAST-SVC whose value may be written and read	Initial value of the Attribute shall be as configured; value shall be non-volatile		X
XX	Representing all DataAttributes as a service parameter	Shall represent all DataAttributes of a DATA (of any FC) to be accessed, for example, to be written and read. The FC value "xx" shall only be used in the functionally constrained data (FCD); "XX" shall not be used as FC value in a DataAttribute	"XX" shall be used as a wildcard in services only		
NOTE The possibility to write an Attribute or a DataAttribute may be further constrained by a view or an implementation.					
^a Column D indicates the use of the FC in the definition of DATA (i.e. common DATA classes in IEC 61850-7-3).					
^b Column CB indicates the use of the FC in the definition of control blocks in this part of IEC 61850.					
^c Reserved for control classes in this part of IEC 61850.					

Annex C
(informative)

Tracking of configuration revisions

		Issue	Impact / Comment	Where is the change made?		configRev	paramRev	valueRev	confRev
				in config file	in IED only				
Configuration	Data Model & Semantic	Semantic change within a logical device	A logical node gets a new semantic use; e.g. a instance of a LN CSWI is now serving a different physical switch or an instance of a logical node PDIS is now used for another zone A data gets a new semantic use; e.g. the use of GGIO.Alm1 changes from "Door open" to "Fire alarm"			X			
		Change of domain data model (Presence of LNs, Data, Data Attributes; Instance names)	available information identification of the information	Through IED configuration tool		X			
Operation / pre configuration	Communication behaviour	Content of data sets; presence of data sets and control blocks	Subscribers of GOOSE or sampled value messages may be affected Preconfigured clients for reporting are affected	Through system configuration tool				X	
		Enabling and disabling control blocks / changing values of control blocks	Message content may not be as expected (reference to data set may change) For sampled values, sample rate may be changed For sampled values, message structure may be changed	Through system configuration tool (Pre configuration)	Communication services or local HMI				X
	Settings and setting groups	Editing values of setting groups (SE)		Through IED configuration tool (Pre configuration)		X			
		Change of a setting (SP)				X			
	Configuration and status attributes	Configuration and status attributes	Change of the value of a CF attribute			Through IED configuration tool (Pre configuration)			X
			Change of the value of a ST attribute	Preconfigured value Changes online only through control services				X	

Page 25: [1] Deleted						Christoph Brunner		03.12.2006 15:18:00	
operTm	TimeStamp	CF							O
Page 36: [2] Deleted						Christoph Brunner		27.04.2007 15:52:00	
<i>measured attributes</i>									
basics									
q	Quality	MX	qchg						M
t	TimeStamp	MX							M
Harmonics and interharmonics									
har	ARRAY[0..numHar] OF Vector	MX	dchg, dupd						M
Page 36: [3] Deleted						Christoph Brunner		27.04.2007 15:52:00	
units	Unit	CF		see Annex A					O
Page 37: [4] Deleted						Christoph Brunner		27.04.2007 15:55:00	
<i>measured attributes</i>									
basics									
q	Quality	MX	qchg						M
t	TimeStamp	MX							M
Harmonics and interharmonics									
phsAHar	ARRAY[0..numHar] OF Vector	MX	dchg, dupd						M
phsBHar	ARRAY[0..numHar] OF Vector	MX	dchg, dupd						O
phsCHar	ARRAY[0..numHar] OF Vector	MX	dchg, dupd						O
neutHar	ARRAY[0..numHar] OF Vector	MX	dchg, dupd						O
netHar	ARRAY[0..numHar] OF Vector	MX	dchg, dupd						O
resHar	ARRAY[0..numHar] OF Vector	MX	dchg, dupd						O
Page 37: [5] Deleted						Christoph Brunner		27.04.2007 15:55:00	
units	Unit	CF		see Annex A					O
Page 38: [6] Deleted						Christoph Brunner		27.04.2007 15:57:00	
<i>measured attributes</i>									
basics									
q	Quality	MX	qchg						M
t	TimeStamp	MX							M
Harmonics and interharmonics									
phsABHar	ARRAY[0..numHar] OF Vector	MX	dchg, dupd						M
phsBCHar	ARRAY[0..numHar] OF Vector	MX	dchg, dupd						O
phsCAHar	ARRAY[0..numHar] OF Vector	MX	dchg, dupd						O
Page 40: [7] Deleted						Christoph Brunner		15.04.2007 16:00:00	
ctIVal	BOOLEAN	CO		off (FALSE) on (TRUE)					AC_CO_M
operTm	TimeStamp	CO							AC_CO_O
Page 41: [8] Deleted						Christoph Brunner		15.04.2007 15:59:00	
ctIVal	BOOLEAN	CO		off (FALSE) on (TRUE)					AC_CO_M
operTm	TimeStamp	CO							AC_CO_O
Page 42: [9] Deleted						Christoph Brunner		15.04.2007 16:01:00	
ctIVal	INT32[CB1]	CO							AC_CO_M
operTm	TimeStamp	CO							AC_CO_O
Page 43: [10] Deleted						Christoph Brunner		15.04.2007 16:03:00	
ctIVal	CODED ENUM	CO		stop lower higher reserved					AC_CO_M

operTm	TimeStamp	CO			AC_CO_O
--------	-----------	----	--	--	---------

Page 44: [11] Deleted Christoph Brunner 15.04.2007 16:05:00

ctIVal	INT8	CO		-64 ... 63	AC_CO_M
operTm	TimeStamp	CO			AC_CO_O

Page 46: [12] Deleted Christoph Brunner 14.10.2006 00:07:00

Common data class specifications for controllable analogue information

Application of services

Table 37 defines the basic controllable analogue information template. In particular, it defines the inheritance and specialisation of services defined in IEC 61850-7-2.

Table 37 – Basic controllable analogue information template

Basic controllable analogue information template					
Attribute Name	Attribute Type	FC	TrgOp	Value/Value Range	M/O/C
DataName	Inherited from Data Class (see IEC 61850-7-2)				
DataAttribute					
<i>setpoint and measured attributes</i>					
<i>configuration, description and extension</i>					
Services (see IEC 61850-7-2)					
The following services are inherited from IEC 61850-7-2. They are specialised by restricting the service to attributes with a functional constraint as specified below.					
Service model of IEC 61850-7-2	Service	Service applies to Attr with FC		Remark	
Data model	SetDataValues GetDataValues GetDataDefinition	DC, CF ALL ALL			
Data set model	GetDataSetValues DataSetValues	ALL DC, CF			
Reporting model	Report	ALL		as specified within the data set that is used to define the report content	
Control model	Operate TimeActivatedOperate	SP SP			

All common data classes for controllable analogue information include both the set point and the related analogue information.

Page Break

Controllable analogue set point information (APC)

Table 38 defines the common data class “controllable analogue set point information”.

Table 38– Controllable analogue set point information

APC class					
Attribute Name	Attribute Type	FC	TrgOp	Value/Value Range	M/O/C
DataName	Inherited from Data Class (see IEC 61850-7-2)				
DataAttribute					
<i>setpoint and measured attributes</i>					
setMag	AnalogueValue	SP, MX	dchg		M
origin	Originator	SP, MX			O
operTm	TimeStamp	SP			O
q	Quality	MX	qchg		M
t	TimeStamp	MX			M
<i>configuration, description and extension</i>					
ctlModel	CtlModels	CF			M
units	Unit	CF		see Annex A	O
sVC	ScaledValueConfig	CF			AC_SCAV
minVal	AnalogueValue	CF			O

maxVal	AnalogueValue	CF			O
stepSize	AnalogueValue	CF		1 ... (maxVal - minVal)	O
d	VISIBLE STRING255	DC		Text	O
dU	UNICODE STRING255	DC			O
cdcNs	VISIBLE STRING255	EX			AC_DLNDA_M
cdcName	VISIBLE STRING255	EX			AC_DLNDA_M
dataNs	VISIBLE STRING255	EX			AC_DLN_M
Services					
As defined in Table 37					