



COMPILATION OF COMMENTS ON COMMITTEE DRAFT

Project number: IEC 61850-9-2 Ed. 2.0	Reference number of the CD 57/800/CD
IEC/TC or SC TC 57	Date of circulation 2006-09-01

Title of the TC or SC:
Power systems management and associated information exchange

Title of the committee draft:
Communication networks and systems in substations – Part 9-2: Specific Communication Service Mapping (SCSM) - Sampled values over ISO/IEC 8802-3

The above-mentioned document was distributed to National Committees with a request that comments be submitted

Comments received – see annex ¹⁾

DECISION OF THE CHAIRMAN (in cooperation with the secretariat)

a A revised committee draft will be distributed as a committee draft for vote (CDV) by (date) 2006-12

b A revised committee draft will be distributed for comment by (date)

c The committee draft and comments will be discussed at the next meeting (date)

NOTE In the case of a proposal a or b made by the chairman, P-members objecting to such a proposal shall inform the Central Office with copy to the secretary in writing within 2 months of the circulation of this compilation (see ISO/IEC Directives, Part 1, 2.5.3).

Name or signature of the Secretary Germany, Dr. Andreas Huber (2006-08-21)	Name or signature of the Chairman T. Lefebvre (2006-08-28)
---	---



Annex

Date 2006-03-13	Document 57/800/CD IEC 61850-9-2 Ed. 2.0
--------------------	--

National Committee	Clause/ Subclause	Paragraph Figure/ Table	Type of comment (General/ Technical/Editorial)	COMMENTS	Proposed change	OBSERVATIONS OF THE SECRETARIAT on each comment submitted
AU	8.2.1 and 8.3.1	Table 9 and 12	Editorial	In Tables 9 & 12 (MSVCB & USVCB structures), suggest the MMS component name "sample-synchronised" be preserved to maintain compatibility with Edition 1.0 rather than replacing it with "Reserved".		Comment accepted. MMS component name will be preserved as "sample synchronized". Appropriate comment will be changed to: Value will be ignored to ensure backward compatibility to IEC 61850-9-2 Edition 1.0